

HADNOT POINT WATER TREATMENT PLANT

ppb

DETECTION LIMIT: 10 ppb

SAMPLE POINT	RAW	TREATED	601	602	603	604	605	634	637	642
SAMPLE DATE	12/4/84	12/4/84	12/4/84	12/20/84	12/4/84	12/4/84	12/4/84	12/4/84	12/4/84	12/4/84
BENZENE	0	0	0	121	0	0	NO	NO	NO	NO
CHLOROFORM	10	16					PEAKS	PEAKS	PEAKS	PEAKS
BROMODICHLOROMETHANE	6	10					PEAKS	PEAKS	PEAKS	PEAKS
TRICHLOROETHYLENE	46	196	207	1400	4.6	110	↓	↓	↓	↓
TRANS 1,2-DICHLOROETHYLENE	15	83	88	630		5.4	↓	↓	↓	↓
1,1,2-TETRACHLOROETHANE	0	0		24			↓	↓	↓	↓

WELL 602 SHUT DOWN 30 NOV 1984. WELLS ~~601, 603~~ 601-605 SHUT DOWN ON 6 DEC 1984

ABOVE SAMPLES SHIPPED OUT ON 4 DEC 1984 BY FEDERAL EXPRESS.

6

SAMPLE POINT	TREATED	601	602	603	604	605	634	637	642
SAMPLE DATE	12/8/84	12/14/84	12/10/84	12/16/84	12/10/84	12/10/84	12/10/84	12/10/84	12/10/84
BENZENE	0	0	720	NO	0				
CHLOROFORM	30			PEAKS					
TRICHLOROETHYLENE	2.3	230	540	↓	15				
TRANS 1,2-DICHLOROETHYLENE	2.3	99	380	↓	2.4				
METHYLENE CHLORIDE	0	10	0	↓	14	180	275	38	

ABOVE SAMPLES SHIPPED OUT ON 11 DEC 1984 BY FEDERAL EXPRESS.

RAW WAS TAKEN ON 13 DEC 1984, 14 DEC 1984

CLW

QUALITY CONTROL SAMPLES OF 602 WERE TAKEN ON 13 DEC 1984.

0000001054

RAW WATER @ HADNOT POINT

SAMPLE DATE	12/3/84	12/4/84	ppb				12/19/84	Date of Analysis FC-540 12/19/84
			12/15/84	12/16/84	12/17/84	12/18/84		
CHLOROFORM	10	11	10	4.3	3.1	4.2	4.6	9.4
BROMODICHLOROMETHANE		6.1	5.5	4.4	2.5			5.4
METHYLENE CHLORIDE	54							
CHLORO-DIBROMOMETHANE						3.0	2.4	5.4
TCE								1.2

60Z ON 12/13/84

□ TCE 340 ppb

TRANS 1,2-DICHLOROETHYLENE 230 ppb

□ INEENE 230 ppb

TOLUENE 12 ppb

CLW

0000001055