

2.185

M-AS(H) NR/ Cam - Geiger WATER Supply System Results from Testing Done After wells with high Chlorides Shutdown

Sample Location	Sample Date/	Chloroform	DichloroBromo methane	Chlorodibromo methane	Bromoform	TOTAL
AS 110, (PLANT)	17 July	2	2	14	63	81
	24 July	5	8	13	7	33
	(Change)	(+3)	(+6)	(-1)	(-56)	(-48)
G-6-50	17 July	2	9	46	146	203
	24 July	6	15	30	27	78
	(Change)	(+4)	(+6)	(-16)	(-119)	(-125)
AS 403A	17 July	2	8	39	139	188
	24 July	8	17	30	23	78
	(Change)	(+6)	(+9)	(-9)	(-116)	(-110)
BID 710	17 July	2	7	31	115	155
	24 July	7	14	25	16	62
	(Change)	(+5)	(+7)	(-6)	(-99)	(-93)
BID 2800	17 July	2	6	32	132	172
	24 July	14	21	35	18	88
	(Change)	+12	(+15)	(+3)	(-114)	(-84)

OVERALL AVERAGE

17 July = 159.8
 24 July = 67.8
 (Change) = (-92.0) 57.6%

CLW

0000001289

29 July 85 FoneCon
 Received from
 Dave Goodwin (Code 114)

CASPER
 A) STATE WILL TAKE A SAMPLE
 J DANNY WILL TAKE ANOTHER
 ROUND OF SAMPLES 7/31
 (GSJ)(7/29)