

0332
4



North Carolina Department of Human Resources
Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

David T. Flaherty, Secretary

July 29, 1988

Commanding Officer
MCAS New River
Jacksonville, NC 28540

RE: Officer's Club
Potable Water Supply
I.D. 04-67-042, Onslow County

Dear Sir:

I visited the Officer's Club at MCAS New River on 20 July 88 to continue our investigation into positive bacteriological reports from the potable water supply at this location.

The procedure we outlined for disinfecting the building's water service lines was followed by the MCB Camp Lejeune Utilities Division with multiple samples performed by the Laboratory Unit from the NREA Division beginning on 18 July 1988.

Water samples collected during my visit indicated coliform bacteria is no longer present at this service and this service should therefore be acceptable for potable service (results enclosed).

Attention should be directed to the standard plate count results from these samples, especially from the portable water supply tank wagon. This analysis is a non-selective indicator of overall bacteriological activity within a water sample.

Thanks again for your continued cooperation and assistance. If we can offer assistance or answer questions, please contact this office.

Sincerely,

J. Fred Hill
Water Supply Consultant
Public Water Supply Branch
Division of Health Services

CLW

bc

0000001791

cc: Commanding General, MCB Camp Lejeune
Commanding Officer, Naval Hospital
Onslow County Health Department
W. E. Venrick
M. P. Bell

Memorandum
6280/4

DATE: 8/5/82
FROM: AC/S Facilities, MCB
TO: CO, MCAS
(Attn: Ground Safety Mgr / Mrs. Wheat)
SUBJ: "0" Club Water Samples

Forwarded to your records.

YR

Bob Alexander

Copy to: NREAD

BMO (Utilities)

CLW

0000001792