

0339

6288/3b
NREAD
SEP 14 1988

From: Director, Natural Resources and Environmental Affairs Division
To: Assistant Chief of Staff, Facilities

Subj: INSTALLATION RESTORATION (IR) PROGRAM INTERIM ALTERNATIVE 3.1 WATER
SUPPLY WELL ASSESSMENT

Ref: (a) NREAD ltr 5200 NREAD dtd 2 Aug 88

Encl: (1) JTC Data Report #88-357

1. In accordance with enclosure (1) of the reference, Water Supply Wells 642, 603 and Hadnot Point Water Treatment Plant (HP) were sampled 11 August 1988 and sent to JTC Environmental Consultants, Inc. for analysis for Volatile Organic Chemical (VOC) scan including methyl ethyl ketone, methyl iso-butyl ketone, and xylene. Enclosure (1) contains the analysis results. In summary, no VOCs were detected at a detection level of 10 ppb.

J. I. WOOTEN

Copy to:
Nav Hosp (OPMS)
BSafety

Blind copy to:
Env Eng
→ BMaintDiv (Util Br)
SWES (2)

CLW

0000001807