

0473A

State of North Carolina  
Department of Environment,  
Health and Natural Resources  
Division of Environmental Health  
Public Water Supply Section



James B. Hunt, Jr., Governor  
Jonathan B. Howes, Secretary  
Linda C. Sewall, Director

December 10, 1996

Mr. Jim Mertsching, Contract Manager  
Sauer, Incorporated  
11223 Phillips Parkway Drive, East  
Jacksonville, Florida 32256-1574

Re: Anthracite Media Sample #0171 15  
Camp Lejeune Water Plant  
U.S. Marine Corps Base  
Onslow County, North Carolina

Dear Mr. Mertsching:

Results of analysis of the reference are as follows:

- |    |                        |      |
|----|------------------------|------|
| a. | Effective size         | 0.78 |
| b. | Uniformity coefficient | 1.51 |
| c. | Dust content (%)       | 0.20 |

Based on the above information, this media is approved for its intended use.

Sincerely,

J. C. Lin, P.E., Head  
Plan Review Branch  
Public Water Supply Section

JCL:jp

cc: M. P. Bell, Regional Engineer  
Onslow County Health Department  
Camp Lejeune Marine Corps Base ✓

From: Pat Rapert  
12/16

CLW

0000002692

