

11330/1
NREAD
5 Mar 1985

Mr. John McFadyen
Water Supply Branch
Division of Health Services
North Carolina Department of
Human Resources
Post Office Box 2091
Raleigh, North Carolina 27602

Dear Mr. McFadyen:

Enclosed are the completed Department of Health Forms (Form 1147
2/74) for all water treatment plants aboard Marine Corps Base,
Camp Lejeune for the period 1-28 February 1985. Also enclosed
are the weekly Chemical Analysis Forms (MCBCL 11330/3 Rev 3-82)
for the same period, as requested in the 25 October 1982 letter
from Mr. Charles Rundgren of your office.

The analysis is run by the Quality Control Laboratory located in
the Natural Resources and Environmental Affairs Division, Assis-
tant Chief of Staff, Facilities. Ms. Elizabeth Betz, Supervisory
Chemist, Quality Control Laboratory, telephone (919) 451-5977 is
the point of contact in this matter.

Sincerely,

J. I. WOOTEN
Director

Encl:

- (1) Dept of Health Forms
- (2) Chemical Analysis Forms

Copy to:

LANTDIV (Code 114)

Blind copy to:
BMO (Attn: UtilDir)

SupvChem

CLW

0000004694

Writer: E. Betz, NREAD 5977
Typist: J. Cross. 5Mar85

Serial # 04-67-041

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM COLIFORMS (MFP)					REPEAT SAMPLES			INCUBATOR TEMP.				
	A		B		C								1	2	3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.		COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES																			
1																									
2																									
3																									
4																									
5																									
6	55											0	9	0	0	0	0	0	0	0	0	0	35.0		
7																									
8																									
9																									
10																									
11																									
12	512											0	8	0	0	0	0	0	0	0	0	0	35.0		
13																									
14																									
15																									
16																									
17																									
18																									
19	511											0	9	0	0	0	0	0	0	0	0	0	35.0		
20																									
21																									
22																									
23																									
24																									
25																									
26	526											0	9	0	0	0	0	0	0	0	0	0	35.0		
27																									
28																									
29																									
30																									
31																									
MF MEDIA		BRI mEndo		BACTERIAL DENSITY		ARITH. MEAN		GEO. MEAN		0000004695		0	DIST. SYSTEM	TOTAL NO. SAMPLES					SAMPLES EXCEEDING 3/50 (4/100) 7/200, 13/500ml			37	0		

Laboratory Cont. #37807

CLW

35.0

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	FINISHED	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	INCUBATOR TEMP.	PLANKTON RAW WATER				
	A		B		C									COLIFORMS (MFP)										REPEAT SAMPLES			
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES								1	2	3	4	5						COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.
1																											
2																											
3																											
4																											
5																											
6																											
7																											
8																											
9																											
10																											
11																											
12																											
13																											
14																											
15																											
16																											
17																											
18																											
19																											
20																											
21																											
22																											
23																											
24																											
25																											
26																											
27																											
28																											
29																											
30																											
31																											
MF MEDIA	BBI mEndo		BACTERIAL DENSITY	ARITH. MEAN		GEO. MEAN																					
TPC MEDIA																											

CLW
0000004696

Serial # 04-67-043

N. C. DEPARTMENT OF HUMAN RESOURCES

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	INCUBATOR TEMP.	PLANKTON							
	A		B		C								COLIFORMS (MFP)										REPEAT SAMPLES						
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES							1	2	3	4	5						COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.				
1																													
2																													
3																													
4																													
5																													
6	LM																												
7																													
8																													
9																													
10																													
11																													
12	LM																												
13																													
14																													
15																													
16																													
17																													
18																													
19	LM																												
20																													
21																													
22																													
23																													
24																													
25																													
26	LM																												
27																													
28																													
29																													
30																													
31																													
MF MEDIA		BRI mEndo		BACTERIAL DENSITY		ARITH. MEAN																							
TPC MEDIA																													

CLW
0000004697

0 DIST. SYSTEM TOTAL NO. SAMPLES 28
SAMPLES EXCEEDING 3/50. (4/100) 7/200. 13/500ml 0

407007

01-11-85

01-11-85

Serial # 04-67-044

N. C. DEPARTMENT OF HUMAN RESOURCES

DATE	RAW WATER COLIFORMS (MFP)									NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM										INCUBATOR TEMP.	PLANKTON RAW WATER	
	A			B			C									COLIFORMS (MFP)					REPEAT SAMPLES							
	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES							1	2	3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.			COLIFORMS per 100 ml.
1																												
2																												
3																												
4																												
5														0	3	0	0	0										350
6																												
7																												
8																												
9																												
10																												
11																												
12														0	3	0	0			0								350
13																												
14																												
15																												
16																												
17																												
18																												
19														0	3	0	0					0						350
20																												
21																												
22																												
23																												
24																												
25																												
26														0	3	0	0						0					350
27																												
28																												
29																												
29																												
30																												
31																												
MF MEDIA	BRL mEndo			BACTERIAL DENSITY	ARITH. MEAN		GEO. MEAN		0000004698					0	DIST. SYSTEM	TOTAL NO. SAMPLES					12							
TPC MEDIA														10		SAMPLES EXCEEDING 3/50. (4/100, 7/200, 13/500ml)					0							

#37807

Blue Hill CRT. Cont. Grade B-Well No. 4087-W

DATE	RAW WATER COLIFORMS (MFP)									NO. OF COLIFORMS PER 100 ml.	FILTERED		FINISHED		TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					INCUBATOR TEMP.	PLANKTON RAW WATER			
	A			B			C				AVE. COLIFORMS per 100 ml.	NO. OF SAMPLES EXAMINED	COLIFORMS (MFP)					REPEAT SAMPLES							
	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES				1	2		3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.			COLIFORMS per 100 ml.		
1																									
2																									
3																									
4																									
5												0	3	0	0	0									35.0
6																									
7																									
8																									
9																									
10																									
11																									
12												0	3	0		0	0								35.0
13																									
14																									
15																									
16																									
17																									
18																									
19												0	3	0			0	0							35.0
20																									
21																									
22																									
23																									
24																									
25																									
26												0	3	0					0	0					35.0
27																									
28																									
29																									
30																									
31																									
MF MEDIA	BRL mEndo			DACTERIAL DENSITY		ARITH. MEAN		GEO. MEAN		0000006599		0	DIST. SYSTEM	TOTAL NO. SAMPLES					12						
TPC MEDIA												1.0		SAMPLES EXCEEDING 3/50. (4/100. 1/200. 13/500ml)					0						

Laboratory Cert. #37807

Signed *Elizabeth A. Boly* Cert. Grado B-Well No. 4087-W

DATE	RAW WATER COLIFORMS (MFP)									NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					INCUBATOR TEMP.	PLANKTON RAW WATER							
	A			B			C									COLIFORMS (MFP)							REPEAT SAMPLES						
	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES							AVE. COLIFORMS per 100 ml.	NO. OF SAMPLES EXAMINED	1	2	3			4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.		
1																													
2																													
3																													
4																													
5																	0	3	0	0	0								35.0
6																													
7																													
8																													
9																													
10																													
11																													
12																0	3	0	0	0									35.0
13																													
14																													
15																													
16																													
17																													
18																													
19																0	3	0	0		0								35.0
20																													
21																													
22																													
23																													
24																													
25																													
26																0	3	0	0			0							35.0
27																													
28																													
29																													
30																													
31																													
MF MEDIA	BBL mEndo			DACTERIAL DENSITY	ARITH. MEAN	0000004/00						0	DIST. SYSTEM	TOTAL NO. SAMPLES					18										
TPC MEDIA				GEO. MEAN							1.0		SAMPLES EXCEEDING 3/50. (4/100) 7/200. 13/500ml					0											

Laboratory Cert. #37807

Signed *Elizabeth A. Bely* Cert. Grade B-Well No. 4087-W

Year 1985

REPORT OF BACTERIOLOGICAL RESULTS TO DIVISION OF HEALTH SERVICES
N. C. DEPARTMENT OF HUMAN RESOURCES

Contaminant Code: 3000

Serial # 04-67-047

DATE	RAW WATER COLIFORMS (MFP)						NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	DISTRIBUTION SYSTEM					COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	INCUBATOR TEMP.	PLANKTON					
	A		B		C								COLIFORMS (MFP)										REPEAT SAMPLES				
	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES							1	2	3	4	5						COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.		
1																											
2																											
3																											
4																											
5																											
6												0	4	0	0			0	0								
7																											
8																											
9																											
10																											
11																											
12												0	4	0	0	0	0										35.0
13																											
14																											
15																											
16																											
17																											
18																											
19												0	4	0	0	0											35.0
20																											
21																											
22																											
23																											
24																											
25																											
26												0	4	0	0	0											35.0
27																											
28																											
29																											
30																											
31																											
MF MEDIA	BBL mEndo		BACTERIAL DENSITY	ARITH. MEAN		GEO. MEAN						0	DIST. SYSTEM	TOTAL NO. SAMPLES					16								
TPC MEDIA												10		SAMPLES EXCEEDING 3/50. (4/100) 7/200. 13/500=1					0								

CLW

0000004701

DATE	RAW WATER COLIFORMS (MFP)									FILTERED		FINISHED		DISTRIBUTION SYSTEM										INCUBATOR TEMP.	PLANKTON			
	A			B			C			NO. OF COLIFORMS PER 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	MFP COLIFORMS per 100 ml.	TOTAL PLATE COUNT	COLIFORMS (MFP)					REPEAT SAMPLES							
	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES	VOLUME FILTERED ml.	TOTAL COLONIES	COLIFORM COLONIES							1	2	3	4	5	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	COLIFORMS per 100 ml.			COLIFORMS per 100 ml.	COLIFORMS per 100 ml.	
1																												
2																												
3																												
4																												
5																												
6																												
7																												
8																												
9																												
10																												
11																												
12																												
13																												
14																												
15																												
16																												
17																												
18																												
19																												
20																												
21																												
22																												
23																												
24																												
25																												
26																												
27																												
28																												
29																												
30																												
31																												
MF MEDIA	BBL mEndo			BACTERIAL DENSITY	ARITH. MEAN		GEO. MEAN		0000004702				0	DIST. SYSTEM	TOTAL NO. SAMPLES					SAMPLES EXCEEDING 3/50. 4/100. 7/200. 13/500ml					8			

Laboratory Cert. #37807

Signed *Elizabeth A. Bely* Cert. Grade B-Well No: 4087-W

CHEMICAL ANALYSIS — WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 6-84)

DATE COLLECTED
 5 FEB 85

DATE OF ANALYSIS
 5 FEB 85

PARAMETER SERIAL # 01-67	HADNOT POINT -041	CAMP JOHNSON -045	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	8.9	7.7	8.9	7.6	8.4	8.3	8.4	8.6		
PHENOLTHALEIN ALKALINITY	6	0	6	0	8	6	6	14		
METHYL ORANGE ALKALINITY	64	198	46	168	192	166	98	192		
CARBONATES AS CaCO ₃	12	0	12	0	16	12	12	28		
BICARBONATES AS CaCO ₃	52	198	34	168	176	154	86	164		
CHLORIDES AS Cl	10	38	10	22	20	16	10	162		
HARDNESS AS CaCO ₃	62	200	60	56	66	48	90	64		
IRON AS Fe		MACHINE DOWN FOR CONSTRUCTION								
FLUORIDE AM	1.15	0.17	1.02	0.18	0.11	0.10	0.85	0.77		
FLUORIDE PM	1.11		0.99				0.82			
CHLORINE RESIDUAL	1.1	1.3	1.0	1.6	1.4	1.0	1.0	1.6		
TURBIDITY AM	0.3	1.0	0.2	0.3	0.3	0.3	1.1	0.2		
TURBIDITY PM	0.2		0.9				0.6			
TOTAL PHOSPHATE		1.00			0.92					
ORTHO PHOSPHATE		0.66			0.16					
META PHOSPHATE		0.34			0.76					
STABILITY	+0.6	-0.3	+0.6	-0.6	+0.1	0.0	+0.2	+0.2		

REMARKS

CLW

0000004703

COPY TO:

UTIL DIR _____

WATER TREATMENT

PMU MCAS PMU

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

CHEMICAL ANALYSIS — WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 6-84)

DATE COLLECTED

2/12/85

DATE OF ANALYSIS

2/12/85

PARAMETER SERIAL # 01-67	HADNOT POINT -041	CAMP JOHNSON -045	TARAWA TERRACE -044	ONSLOW BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	9.0	7.3	8.8	7.4	8.3	8.3	8.6	8.2		
PHENOLTHALEIN ALKALINITY	8	0	4	0	2	2	4	0		
METHYL ORANGE ALKALINITY	50	196	52	160	150	150	70	200		
CARBONATES AS CaCO ₃	16	0	8	0	4	4	8	0		
BICARBONATES AS CaCO ₃	34	196	44	160	146	146	62	200		
CHLORIDES AS Cl	10	50	10	20	16	18	14	160		
HARDNESS AS CaCO ₃	60	68	82	62	56	56	74	84		
IRON AS Fe	<0.04	0.51	0.06	0.20	0.09	0.06	<0.04	0.09		
FLUORIDE	0.96 0.93	0.17	0.16 0.83	0.17	0.12	0.09	0.73 0.72	0.70		
CHLORINE RESIDUAL	1.2	1.2	1.0	1.2	1.5	1.0	1.0	1.1		
TURBIDITY	0.20 0.20	0.50	6.6 0.40	0.30	0.70	0.30	0.40 0.30	0.40		
TOTAL PHOSPHATE		1.30			1.26					
ORTHO PHOSPHATE		1.00			0.25					
META PHOSPHATE		0.30			1.01					
STABILITY	+0.4	-0.8	+0.6	-0.9	0.0	+0.1	+0.3	0.0		

REMARKS

CLW

0000004704

COPY TO:

UTIL DIR _____

WATER TREATMENT

PMU MCAS PMU

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

CHEMICAL ANALYSIS — WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 6-84)

DATE COLLECTED

19 FEB 85

DATE OF ANALYSIS

19 FEB 85

PARAMETER SERIAL # 01-67	HADNOT POINT -041	CAMP JOHNSON -045	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IN LAB NOT PLANT)	8.7	7.6	8.8	7.6	8.6	8.4	8.9	9.1		
PHENOLTHALEIN ALKALINITY	10	0	6	0	10	8	10	26		
METHYL ORANGE ALKALINITY	20	190	56	164	172	164	56	170		
CARBONATES AS CaCO ₃	20	0	12	0	20	16	20	52		
BICARBONATES AS CaCO ₃	0	190	44	164	152	148	36	118		
CHLORIDES AS Cl	12	42	12	22	22	22	16	160		
HARDNESS AS CaCO ₃	76	86	80	70	70	60	68	60		
IRON AS Fe	<0.04	0.57	<0.04	0.14	0.09	0.07	0.06	<0.04		
FLUORIDE	0.91 0.88	0.16	1.00 1.04	0.16	0.11	0.09	0.96 0.88	0.70		
CHLORINE RESIDUAL	1.1	1.2	1.0	1.3	1.3	1.0	0.9	1.3		
TURBIDITY	0.3 0.3	0.4	0.2 0.2	0.3	0.3	0.2	0.3 0.5	2.3		
TOTAL PHOSPHATE		2.05			1.68					
ORTHO PHOSPHATE		1.13			0.25					
META PHOSPHATE		0.92			1.43					
STABILITY	+0.2	-0.4	+0.3	-0.6	+0.3	+0.1	+0.3			

REMARKS

CLW

0000004705

COPY TO:

UTIL DIR _____

WATER TREATMENT

PMU MCAS PMU

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

CHEMICAL ANALYSIS -- WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 6-84)

DATE COLLECTED

26 FEB 85

DATE OF ANALYSIS

26 FEB 85

PARAMETER SERIAL # 01-47	HADNOT POINT -041	CAMP JOHNSON -042	TARAWA TERRACE -044	ONSLow BEACH -048	COURTHOUSE BAY -047	RIFLE RANGE -046	HOLCOMB BLVD -043	NEW RIVER -042		
PH (IK LAB NOT PLANT)	8.8	7.4	8.8	7.5	8.4	8.3	8.8	8.5		
PHENOLTHALEIN ALKALINITY	4	0	4	0	6	2	6	4		
METHYL ORANGE ALKALINITY	44	190	54	160	148	158	60	180		
CARBONATES AS CaCO ₃	8	0	8	0	12	4	12	8		
BICARBONATES AS CaCO ₃	36	190	46	160	136	154	48	172		
CHLORIDES AS Cl	10	36	8	14	18	12	16	186		
HARDNESS AS CaCO ₃	56	80	74	60	60	60	60	64		
IRON AS Fe	<0.04	0.74	<0.04	0.10	<0.04	<0.04	<0.04	<0.04		
FLUORIDE Am Pm	1.07 1.01	0.57	1.10 1.08	0.17	0.12	0.10	1.11 1.02	0.82		
CHLORINE RESIDUAL	1.0	1.3	1.0	1.5	1.4	1.0	1.0	1.3		
TURBIDITY Am Pm	0.4 0.5	1.2	0.2 0.3	0.2	0.2	0.2	0.3 0.4	0.4		
TOTAL PHOSPHATE		1.54			1.84					
ORTHO PHOSPHATE		0.90			0.19					
META PHOSPHATE		0.64			1.65					
STABILITY	+0.2	-0.8	+0.2	-0.8	0	-0.2	+0.1	-0.1		

REMARKS

CLW

0000004706

COPY TO:

UTIL DIR _____

WATER TREATMENT

PMU MCAS PMU

NREAD FILE

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY
 T.N. BARBEE