

31 Oct 1985

6280/5
NREAD

Director, Natural Resources and Environmental Affairs Division,
Marine Corps Base, Camp Lejeune
Assistant Chief of Staff, Facilities, Marine Corps Base, Camp
Lejeune

TARAWA TERRACE POTABLE WATER SUPPLY, WELL #TT-25

Encl: (1) SupvChemist, NREAD memo of 31 Oct 1985

1. The enclosure is provided for your information. It is recommended that sampling for volatile organics be limited to finished water, and on a weekly basis. Please advise.

J. I. WOOTEN

Writer: J. I. WOOTEN, NREAD 5003
Typist: J. Cross 31Oct85

CLW
0000004901

Memorandum

DATE: 31 October 1985

FROM: Supervisory Chemist, Water Quality Control Lab, Environmental Branch

TO: Supervisory Ecologist, Environmental Branch *DDB*

SUBJ: TT-25

1. Anne Rosecrance from JTC called today with the analysis of the 29 October 1985 sampling of TT-25 well. JTC did not detect any volatile organics in TT-25. Ms. Rosecrance said their detection level is 10 ppb but they can see as low as 2 ppb. Nothing was detected in TT-25. Hadnot Point and Tarawa Terrace treated, collected 29 October 1985, only showed Trihalomethanes. Their results are shown below:

<u>System</u> (units = ppb)	<u>HP</u>	<u>TT</u>
Chloroform	11	2
Dichlorobromomethane	7	5
Dibromochloromethane	4	9
Bromoform	Non-detected	6

Elizabeth A. Betz
ELIZABETH A. BETZ

CLW

0000004902

ENCLOSURE (1)