

CLW

0000005011

12-27-00 HAO Shift Foreman Check 637 wells

logs  
closed  
not for  
it Pa  
after  
1995

CONTAMINATED WELLS AT CAMP LEJEUNE								
Tetrachloroethylene - PCE    Dichloroethane - DCE    Trichloroethylene - TCE								
Well	Construction Date	Sampled Date	Primary Contaminate	Contaminate Level (ppb)	Secondary Contaminant	Contaminate Level (ppb)	Out of Service Date	Remarks
<b>Tarawa Terrace Water Treatment Plant</b>								
TT-23	1984	1/16/85	PCE	132	DCE	11	2/8/85	Returned to service on 4/22/85, 4/23/85, and 4/29/85 for 7 hour periods to maintain critical reservoir level
TT-25	1982	1/16/85 1/23/85	PCE Not Detected	Trace			1/14/87	
TT-26	1952	1/16/85	PCE	1580	DCE	92	2/8/85	
<b>Hadnot Point Water Treatment Plant</b>								
601	1941	12/4/84	TCE	207	DCE	88	12/6/84	
602	1941	11/30/84	TCE	1600	DCE	630	11/30/84	
603	1941	12/4/84 12/10/84 1/23/85	TCE Not Detected Not Detected	4.6			5/5/85	Returned to service
			TCE	3			2/16/96	
608	1941	12/4/84	TCE	110	DCE	5.4	12/6/84	
610	1941	10/1/92	TCE	37			12/18/92	
634	1960	12/10/84	Methylene Chloride	130			12/14/84	
637	1970	12/10/8 8/26/92	Methylene Chloride Not Detected	275			12/14/84	Returned to service 6/9/93 Well secured due to close proximity to IR site
							1/26/95	
638	1970	9/28/92	Benzene	?			11/10/92	
651	1972	2/4/85	TCE	18,900	DCE	8070	2/4/85	
652	1972	1/16/85 10/14/93	TCE Not Detected	9			2/8/85	Returned to service
653	1978	2/4/85	TCE	5.5			2/8/85	
660	1984	6/6/85	TCE	2.6			12/6/85	Not used for drinking water production
LCH-4007	1942	1/12/98	DCE	1.3			2/25/99	
<b>Holcomb Boulevard Water Treatment Plant</b>								
645	1972	11/4/86	Benzene	20			1/13/87	Well not used since November 1986
706	1987	8/4/98	Benzene	4.7	DCE	?	3/10/98	Closed as a precaution until sampling conducted
<b>Marine Corps Air Station Water Treatment Plant</b>								
TC-700	1941	1/12/98	Benzene	2.6			5/1/98	
AS-106	1954	8/30/93	Not Detected				1/13/87	No records found Returned to service
		1/12/99	DCE	2.4			9/1/95 2/25/99	Well secured due to close proximity to IR site Permanently closed

AS-4150	1969	12/4/84 9/18/93	TCE Not Detected	Trace			2/4/85	Returned to service
<b>Rifle Range Water Treatment Plant</b>	1965							
RR-229	1984	2/4/85	TCE	3.2			2/4/85	Not used for drinking water production

Note (1): Table data based on best available information and records as of 12/27/00

Note (2): Current drinking water Maximum Contaminant Levels (MCL): TCE – 5 ppb; DCE – 7.0 ppb; Benzene - 5.0 ppb; Methylene Chloride – 5 ppb

Note (3): Water wells removed from service after 1985 resulted from special and regular monitoring.

Note (4): Raw water wells are sampled annually and water plants are sampled monthly for volatile organic compounds (VOC)

CLW

0000005012