

ROUTINE REPLY, ENDORSEMENT, TRANSMITTAL OR INFORMATION SHEET
NAVEXOS-3989

FROM LANTON CODE 1142 FILE NUMBER 6280
11420.PG

TO MCB CAMP LETAUNE DATE 12 FEB 85
BASE MAINTENANCE, ENVIRONMENTAL AFFAIRS DIVISION

VIA _____ Endorsement on **CLW**

SUBJECT VOA **0000005594**

REFERENCE (A) PITCHONS MCB (Ms. B. Betz / Mr. R. S. S. S. S.) / LANTON (Mr. P. Goddard) of
31 JAN 85 / 11 FEB 85 / 4 FEB 85

ENCLOSURE (1) JTC REPORT 17 (REC'D 12 FEB 85)

FORWARDED RETURNED FOLLOW-UP REQUEST ADVISE SUBMIT

X	MESSAGE	X	MESSAGE	X	MESSAGE
<input checked="" type="checkbox"/>	FOR APPROPRIATE ACTION		SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO YOUR OFFICE AS A MATTER UNDER YOUR JURISDICTION.		OO FORM 250-3 IMMEDIATELY FOR MATERIAL ON SUBJECT PURCHASE DOCUMENT REC'D AT THIS ACTIVITY
	FOR INFORMATION OR CERTIFICATION AND/OR FILE.		SUBJECT DOCUMENTS WAS/WERE APPROVED AND FORWARDED TO YOU.		CERTIFY ENCLOSURE _____ AS TO RECEIPT AND ACCEPTANCE OF MATERIAL AND FORWARD TO _____
	<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED		_____ COPY(IES) OF THIS CORRESPONDENCE WITH YOUR REPLY.		_____ COPIES OF SUBJECT CHANGE ORDER AMENDMENT OR MODIFICATION
	APPROVAL <input type="checkbox"/> IS <input type="checkbox"/> IS NOT RECOMMENDED		ENCLOSURE(S) _____ IS/ARE FORWARDED AS REQUESTED BY REFERENCE _____		CHANGE NOTICE TO THE SUPPLIER
	CONCURRING IN RECOMMENDATIONS MADE IN THE BASIC CORRESPONDENCE.		ENCLOSURE(S) IS/ARE RETURNED FOR CORRECTION AS INDICATED.		_____ COPIES OF APPLICABLE PLANS AND/OR SPECIFICATIONS.
	COMMENTS AND/OR RECOMMENDATIONS.		CORRECTED ENCLOSURE(S) AS REQUESTED		FOR PLAN ACTION AS INDICATED
	MAILING LIST ACTION		SUBJECT PERSON'S ATTENTION SHOULD BE INVITED TO THIS MATTER		CLASSIFICATIONS OF DEFECTS FOR SUBJECT ITEMS
	FOR ASSIGNMENT OF BUREAU FILE NUMBER(S)		SUBJECT PERSON(S) REPORTED TO THIS COMMAND _____		CONFIRMATION THAT INSPECTION OR SOURCE INSPECTION IS NOT REQUIRED
	ON A LOAN BASIS RETURN BY _____		SUBJECT PERSON(S) COMPLETED HIS/THEIR DUTY AND WAS/WERE DETACHED FROM THIS COMMAND _____		INSPECTION UNDER THE SUBJECT SUBCONTRACT IS NOT REQUIRED
	SIGN ORIGINAL RECEIPT AND RETURN TO THIS OFFICE.		NAME AND LOCATION OF SUPPLIER OF SUBJECT ITEMS.		_____ COPIES OF SUBJECT PURCHASE DOCUMENT. IF SOURCE INSPECTION OR PROGRESSING IS REQUIRED
	SUBJECT FILES. WHICH ARE LOCATED IN BOX NO. _____ SHIPMENT NO. _____		SUBCONTRACT NUMBER FOR SUBJECT ITEM _____		STATUS OF MATERIAL ON SUBJECT PURCHASE DOCUMENT
	REPLY TO THE ABOVE REFERENCE(S) BY _____		SUBJECT PURCHASE DOCUMENT HAS BEEN REQUESTED AND WILL BE FORWARDED WHEN RECEIVED.		CLEARANCE AS INDICATED IN BASIC CORRESPONDENCE VERIFIED. NO REPLY UNLESS NEGATIVE.
	_____ COPY(IES) OF REFERENCE DESCRIBED ABOVE WAS/WERE NOT RECEIVED.		ENDORSEMENT _____ OF SUBJECT SUBCONTRACT IS BEING DELAYED PENDING RECEIPT OF BASIC PURCHASE DOCUMENT.		VERIFICATION OF NEED-TO-KNOW FOR VISIT PERSONNEL CLEARANCES VERIFIED.
	SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO _____		APPROPRIATION SYMBOL SUBHEAD AND CHARGEABLE ACTIVITY _____		<u>1. ENCL (H) PROVIDES HARD COPY OF DATA FWD VIA RBIF (A).</u>
	SUBJECT DOCUMENT(S) IS/ARE WAS/WERE RETURNED FOR _____		WHETHER SUBJECT ITEMS ARE TO BE COMMERCIALY SHIPPED OR AT GOVERNMENT EXPENSE _____		SEE REMARKS ON THE REVERSE SIDE.
			A CERTIFICATE IN LIEU OF SUBJECT BILL OF LADING WHICH HAS BEEN LOST.		

COPY TO 114, 1141, 1145 SIGNATURE David Goddard

REPORT #17
LABORATORY ANALYSIS ON
NAVAL SAMPLES
(A/E Contract N6270-84-B-6932
JTC REPORT # 85-046

PREPARED FOR:
DEPARTMENT OF NAVY
ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VA 23511

PREPARED BY:
JTC ENVIRONMENTAL CONSULTANTS, INC.
4 RESEARCH PLACE, SUITE L-10
ROCKVILLE, MARYLAND 20850

FEBRUARY 6, 1985

Ann E. Rosecrance

Ann E. Rosecrance
Laboratory Director

CLW
000005595

JTC Environmental Consultants, Inc.

Date 2-6-85 Report No. 17 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-046 Table 1 Date of Sample Receipt 1-18-85

NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER					
		VOA					
601	12-0382	See attached sheets					
602	12-0383	*					
603	12-0384	See attached sheets					
606	12-0385	"					
608	12-0386	*					
609	12-0387	See attached sheets					
611	12-0388	"					
613	12-0389	"					
614	12-0390	"					
616	12-0391	"					
620	12-0392	"					
621	12-0393	"					
627	12-0394	"					
632	12-0395	"					
633	12-0396	"					
634	12-0397	"					
635	12-0398	"					
636	12-0399	"					
637	12-0400	"					
638	12-0401	"					

CLW

000005596

JTC Environmental Consultants, Inc.

Date 2-6-85 Report No. 17 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-046 Table 2 Date of Sample Receipt 1-18-85


NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER									
		VOA									
639 old	12-0402	See attached sheet									
639 new	12-0403	"									
640	12-0404	"									
641	12-0405	"									
642	12-0406	"									
643	12-0407	"									
644	12-0408	"									
645	12-0409	*									
646	12-0410	See attached sheets									
647	12-0411	"									
648	12-0412	"									
650	12-0413	"									
651	12-0414	"									
652	12-0415	"									
653	12-0416	"									
655	12-0417	"									
LCN 4007	12-0418	"									

CLW

000005597

* Sample bottle broken

Navy Sample #601 Received 1/18/85



JTC ENVIRONMENTAL CONSULTANTS, INC.
 PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL395 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0382 Sample #601
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene ²⁶ N.D.	
30V 1,2-trans-dichloro- ethylene	8.8 N.D.	88V vinyl chloride	N.D.

CLW

000005598

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED

Navi. sample # 603

Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL396 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0384 Sample # 603
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.


CLW

0 00005599

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Na sample # 606 Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 397 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0385 Sample # 606

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 1/27/85


PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

0000005600

ivy sample # 609 Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 398 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0387 sample # 609
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005601

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Ny sample # 611 Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL399 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0388 sample # 611
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005602

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Any sample # 613 Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL400 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0389 sample # 613
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005603

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Ny sample # 614 Received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 401 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0390 Sample # 614
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005604

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED



1 y sample # 616 Received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 402 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0391 Sample # 616
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1/27/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005605

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED



Navy sample 620 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. UGASPL404 PROJECT NO. NE-12

SAMPLE DESIGNATION & DATE 12-0392 #620 NE-12 #17

METHOD NO. 624 DETECTION LIMIT 10 ug/lit


ANALYSIS DATE 01 28 85

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

000005606



Navy sample 621 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VDASPL406 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0393 #621 NF-12 #17
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 01 28 85


PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

0000005607

New Sample 627 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 405 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0394 #627 NF-12
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 01 28 85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

0000005608



Navy sample 632 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL407 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0395 #632
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 01 28 85

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

0000005609



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL444 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0396 #633
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 2-4-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005610

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED



Navy Sample 634 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL408 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0397 #634 NF-12#17

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 01 18 85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D. 10
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	1300 N.D.
30V 1,2-trans-dichloro- ethylene	700 N.D.	88V vinyl chloride	6.8 N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

000005611

Navy sample 635 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 410 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0398 #635 NF-12 #17
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 01-29-85

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloropro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW
000005612

Navy sample 636 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 415 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0399 # 636
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 1-29-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005613

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED



Navy sample 637 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 418 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0400 #637 1/18/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 02/01/85

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

00005614



Navy Sample 638 received 1-18-85

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL419 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0401 # 638 NF-12 1/18/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 02 01 85

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

000005615

Na... sample 639 old received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL420 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0402 # 639 old
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-01-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

0000005616

Navy Sample 639new received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 421 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0403 # 639 new
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW

000005617

Na sample 640 received 1-10-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOA SPL 422 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0404 #640
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85


PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

000005618

Navy sample 641 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 423 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0405 # 641
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85


PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

000005619

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Navy sample 642 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 424 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0406 # 642
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005620

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Navy sample 643 rec'd 2-1-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 425 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0407 # 643

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 2-1-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.


CLW

000005621

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Navy sample 644 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL426 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0408 #644
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

0000005622

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Navy sample 646 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL427 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0410 # 646
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85


PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

000005623

new sample 647 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 428 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0411 #647
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005624

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Truy sample 648 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 429 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0412 #648
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-1-85


PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
<u>2V acrolein</u>	<u>N.D.</u>	<u>32V 1,2-dichloropropane</u>	<u>N.D.</u>
<u>3V acrylonitrile</u>	<u>N.D.</u>	<u>33V 1,3-dichloro- pylene</u>	<u>N.D.</u>
<u>4V benzene</u>	<u>N.D.</u>	<u>38V ethylbenzene</u>	<u>N.D.</u>
<u>6V carbon tetrachloride</u>	<u>N.D.</u>	<u>44V methylene chloride</u>	<u>N.D.</u>
<u>7V chlorobenzene</u>	<u>N.D.</u>	<u>45V methyl chloride</u>	<u>N.D.</u>
<u>10V 1,2-dichloroethane</u>	<u>N.D.</u>	<u>46V methyl bromide</u>	<u>N.D.</u>
<u>11V 1,1,1-trichloro- ethane</u>	<u>N.D.</u>	<u>47V bromoform</u>	<u>N.D.</u>
<u>13V 1,1-dichloroethane</u>	<u>N.D.</u>	<u>48V dichlorobromo- methane</u>	<u>N.D.</u>
<u>14V 1,1,2-trichloro- ethane</u>	<u>N.D.</u>	<u>49V trichlorofluoro- methane</u>	<u>N.D.</u>
<u>15V 1,1,2,2-tetra- chloroethane</u>	<u>N.D.</u>	<u>50V dichlorodifluoro- methane</u>	<u>N.D.</u>
<u>16V chloroethane</u>	<u>N.D.</u>	<u>51V chlorodibromomethane</u>	<u>N.D.</u>
<u>19V 2-chloroethylvinyl ether</u>	<u>N.D.</u>	<u>85V tetrachloroethylene</u>	<u>N.D.</u>
<u>23V chloroform</u>	<u>N.D.</u>	<u>86V toluene</u>	<u>N.D.</u>
<u>29V 1,1-dichloroethylene</u>	<u>N.D.</u>	<u>87V trichloroethylene</u>	<u>N.D.</u>
<u>30V 1,2-trans-dichloro- ethylene</u>	<u>N.D.</u>	<u>88V vinyl chloride</u>	<u>N.D.</u>

CLW

000005625

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

Tr y sample 650 received. 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL431 PROJECT NO. NF-12
SAMPLE DESIGNATION & DATE 12-0413 # 650
METHOD NO. 624 DETECTION LIMIT 10 ug/lit
ANALYSIS DATE 2-2-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005626

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Navy Sample 651 received 1-18-85



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL432 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0414 #651

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 2-2-85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene ³⁸⁶ N.D.	
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene ¹⁸⁷ N.D.		87V trichloroethylene ³²⁰⁰ N.D.	
30V 1,2-trans-dichloro- ethylene ³⁴⁰⁰ N.D.		88V vinyl chloride ⁶⁵⁵ N.D.	

CLW

0000005627

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL434 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0415 #652
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 2/2/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene ^{9.0}	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005628

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED



JTC ENVIRONMENTAL CONSULTANTS, INC.
 PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL 436 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0416 #653
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 2/3/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene <u>5.5</u> N.D.	
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005629

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED



JTC ENVIRONMENTAL CONSULTANTS, INC.
 PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL437 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0417 #655
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 2/3/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005630

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL438 PROJECT NO. NF-12
 SAMPLE DESIGNATION & DATE 12-0418 #LCH4007
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit
 ANALYSIS DATE 2/3/85

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005631

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED