



DEPARTMENT OF THE NAVY  
ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
3333 SOLID AIR BRIDGE CIRCLE, WASHINGTON, D.C. 20340

7571  
TELEPHONE NO.

(804) 444-9566

CONTROL SYMBOL NO.

11300

1143CFB

8 JAN 1985

From: Commander, Atlantic Division, Naval Facilities Engineering Command  
To: Commanding General, Marine Corps Base, Camp Lejuene

Subj: TESTING OF POTABLE WATER WELLS AND WATER TREATMENT PLANT

Ref: (a) LANTNAVFACENGCOM msg 071346Z Dec 1984

Encl: (1) Reports #4, #7, #8, #10, and #12; Laboratory Analysis on Naval Samples by JTC Environmental Consultants, Inc.

1. Reference (a) forwarded preliminary results from testing of potable water wells and recommended additional sampling of Hadnot Point water treatment plant for volatile organics. Enclosure (1), a formal report of the sampling effort to date, is forwarded for your use. Our evaluation and recommendations will follow under separate cover.

R. D. CROWSON P.E.  
Director, Utilities, Energy and  
and Environmental Division

Copy to:  
Environmental Science and Engineering (ESE)  
P. O. Box ESE  
Gainesville, FL 32602  
Attn: Russ Bowen

CLW

0000005632

REPORT # 4 (VOAs ONLY)  
LABORATORY ANALYSIS ON  
NAVAL SAMPLES  
(A/E Contract N6270-84-B-6932  
JTC REPORT # 84-127

PREPARED FOR:  
DEPARTMENT OF NAVY  
ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VA 23511

**CLW**  
**0000005633**

PREPARED BY:  
JTC ENVIRONMENTAL CONSULTANTS, INC.  
4 RESEARCH PLACE, SUITE L-10  
ROCKVILLE, MARYLAND 20850

DECEMBER 18, 1984

*Ann E. Rosecrance*  

---

Ann E. Rosecrance  
Laboratory Director


JTC Environmental Consultants, Inc.

Date 12/18/84 Report No. 4 (VOAs only) to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 84-127 Table 1 Date of Sample Receipt 12-5-84

NAVY SAMPLE ID	JTC SAMPLE ID	Volatile Organics	ANALYSIS PARAMETER			
		VOAs				
Bldg 20 Treated	12-0155	See attached data sheets ↓				
Bldg 20 untreated	12-0156					
Bldg 601	12-0157					
HP 602	12-0158					
Bldg 603	12-0159					
Bldg 608	12-0160					
Bldg 634	12-0161					
Bldg 637	12-0162					
Bldg 642	12-0163					
					CLW 0000005634	

Navy Sample Bldg 20 Treated received 12/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

~~CLW~~

~~000005635~~

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 258 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0155 12/5/84 Bldg 20 Treated  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/5/84

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	9.6* N.D.
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	3.8* N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	3.9* N.D.
23V chloroform	16 <del>N.D.</del>	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	200 N.D.
30V 1,2-trans-dichloroethylene	83 N.D.	88V vinyl <del>CLW</del> ide	N.D.

000005635

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* holds method detection limit

Navy Sample 2 Bldg 20 untreated received 12/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL260 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0156 12/5/84 Bldg 20 untreated  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/5/84

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	6.0* <del>N.D.</del>
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	2.2* <del>N.D.</del>
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	9.6* <del>N.D.</del>	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	46 <del>N.D.</del>
30V 1,2-trans-dichloro- ethylene	15 <del>N.D.</del>	88V vinyl chloride	N.D.


CLW

000005636

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* below method detection limit

Navy samp Bldg 601 received 1, 5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL261 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0157 12/5/84 Bldg 601  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/5/84

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	5.0* N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	210 N.D.
30V 1,2-trans-dichloro- ethylene	88 N.D.	88V vinyl chloride	N.D.


CLW

000005637

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* below method detection limit

Navy Sample HP602 recen & 12/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 262 PROJECT NO. NF-12  
 SAMPLE DESIGNATION & DATE 12-0158 12/5/84 HP602  
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
 ANALYSIS DATE 12/5/84

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	120 <del>N.D.</del>	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene <sup>24</sup>	<del>N.D.</del>
23V chloroform	N.D.	86V toluene	5.4* <del>N.D.</del>
29V 1,1-dichloroethylene	2.4* <del>N.D.</del>	87V trichloroethylene	1600 <del>N.D.</del>
30V 1,2-trans-dichloro- ethylene	630 <del>N.D.</del>	88V vinyl chloride	18 <del>N.D.</del>

CLW

000005638

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* below method detection limit

Navy sample HP603 received 1/5/84

CLW



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

0000005639

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 263 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0159 12/5/84 HP603

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 12/5/84

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	4.6* N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* below method detection limits



Navy sam, 2 HP608 received 12, /84

CLW



JTC ENVIRONMENTAL CONSULTANTS, INC. 0000005640  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION


LAB SAMPLE LOG NO. VOASPL265 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0160 12/5/84 HP608  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/5/84

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	3.7* N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	110 N.D.
30V 1,2-trans-dichloro- ethylene	5.4* N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED

\* below method detection limit

Navy sam, Bldg 634 received 1/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL266 PROJECT NO. NF-12

SAMPLE DESIGNATION & DATE 12-0161 12/5/84 Bldg 634

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

ANALYSIS DATE 12/5/84

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005641

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Navy sam, 2 Bldg 637 received 1/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL 269 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0162 12/5/84 Bldg 637  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/6/84

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005642

N.D. = NOT DETECTED

N.A. = NOT APPLICABLE/ANALYZED

Navy sample Bldg 642 received 2/5/84



JTC ENVIRONMENTAL CONSULTANTS, INC.  
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

LAB SAMPLE LOG NO. VOASPL270 PROJECT NO. NF-12  
SAMPLE DESIGNATION & DATE 12-0163 12/5/84 Bldg 642  
METHOD NO. 624 DETECTION LIMIT 10 ug/lit  
ANALYSIS DATE 12/6/84

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005643

N.D. = NOT DETECTED  
N.A. = NOT APPLICABLE/ANALYZED