

ROUTINE REPLY, ENDORSEMENT, TRANSMITTAL OR INFORMATION SHEET

OPNAV 5216/158 (Rev. 7-78)
SN 0107-LF-052-1691

A WINDOW ENVELOPE MAY BE USED
Formerly NAVEXOS 3789

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

FROM (Show telephone number in addition to address)

Commander, Atlantic Division (804) 444-9558
Naval Facilities Engineering Command

DATE

8 January 1982

SUBJECT

Monitoring data for Trihalomethanes in drinking water

SERIAL OR FILE NO.

114°WLC
6280

TO:

Commanding General
Marine Corps Base
Camp Lejeune, NC 28542
ATTN: Assistant Chief of Staff
for Facilities

REFERENCE

ENCLOSURE

(1) TTHM Surveillance Report Form-Hadnot Poi
(2) TTHM Surveillance Report Form ~~Rifle Range~~ MCAS

VIA:

ENDORSEMENT ON

FORWARDED RETURNED FOLLOW-UP, OR TRACER REQUEST SUBMIT CERTIFY MAIL FILE

GENERAL ADMINISTRATION		CONTRACT ADMINISTRATION		PERSONNEL	
FOR APPROPRIATE ACTION UNDER YOUR COGNIZANCE		NAME & LOCATION OF SUPPLIER OF SUBJECT ITEMS		REPORTED TO THIS COMMAND:	
<input checked="" type="checkbox"/> INFORMATION APPROVAL RECOMMENDED <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED		SUBCONTRACT NO. OF SUBJECT ITEM		DETACHED FROM THIS COMMAND	
COMMENT AND/OR CONCURRENCE		APPROPRIATION SYMBOL, SUBHEAD, AND CHARGEABLE ACTIVITY		OTHER	
CONCUR		SHIPPING AT GOVERNMENT EXPENSE <input type="checkbox"/> YES <input type="checkbox"/> NO			
LOANED, RETURN BY:		A CERTIFICATE, VICE BILL OF LADING			
SIGN RECEIPT & RETURN		COPIES OF CHANGE ORDERS, AMENDMENT OR MODIFICATION			
REPLY TO THE ABOVE BY:		CHANGE NOTICE TO SUPPLIER			
REFERENCE NOT RECEIVED		STATUS OF MATERIAL ON PURCHASE DOCUMENT			
SUBJECT DOCUMENT FORWARDED TO:		REMARKS (Continue on reverse)			
SUBJECT DOCUMENT RETURNED FOR:					
SUBJECT DOCUMENT HAS BEEN REQUESTED, AND WILL BE FORWARDED WHEN RECEIVED					
COPY OF THIS CORRESPONDENCE WITH YOUR REPLY					
ENCLOSURE NOT RECEIVED					
ENCLOSURE FORWARDED AS REQUESTED					
ENCLOSURE RETURNED FOR CORRECTION AS INDICATED					
CORRECTED ENCLOSURE AS REQUESTED					
REMOVE FROM DISTRIBUTION LIST					
REDUCE DISTRIBUTION AMOUNT TO:					
SIGNATURE & TITLE		<p style="text-align: center;">CLW 0000005736</p>			

Wallace L. Carter, Environmental Engineer

COPY TO:

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

TTHM SURVEILLANCE REPORT FORM

MCAS

Installation CAMP LE JEUNE (NEW RIVER)

Date Collected 21 SEP 81 PM

AVE 171

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CHBr ₃	TTHM
WTP 110	546	20.9	25.9	38.6	50.1	136
520	547	30.9	34.1	44.0	60.2	116.9
4025	548	26.3	32.0	50.8	66.9	171.6
710	549	23.7	31.1	48.8	59.3	163
2800	550	25.1	32.9	51.0	65.0	174
Reference OBS						
True						

Date Received 28 SEP 81

Date Analyzed 30 DEC 81

Remarks:

William C Neal
 WILLIAM C. NEAL, JR.
 Chief, Laboratory Services

CLW

000005737

TTHM SURVEILLANCE REPORT FORM

Installation CAMP LE JEUNE (HAONOT)

Date Collected 25 SEP 81 PM

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CHBr ₃	TTHM
20 WTP	461	19.2	56.0	8.8	20.1	114
NH-1	462	56.7 56.0	68.6	9.2	<0.1	135
1202	463	57.2	60.0	11.8	<0.1	129
65	464	56.7	57.0	12.9	<0.1	124
530	465	60.4	50.1	13.9	4.4	132
Reference OBS						
True						

Date Received 28 SEP 81

Date Analyzed 30 DEC 81

Remarks:

William C. Neal, Jr.
 WILLIAM C. NEAL, JR.
 Chief, Laboratory Services

CLW

000005738