

ROUTINE REPLY, ENDORSEMENT, TRANSMITTAL OR INFORMATION SHEET
 OPNAV 5216/158 (Rev. 7-78) A WINDOW ENVELOPE MAY BE USED
 SN 0107-LF-052-1691 Formerly NAVEXOS 3789

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

FROM (Show telephone number in addition to address)

Commander, Atlantic Division, Naval Facilities
 Engineering Command

DATE
 15 December 1981

SUBJECT
 Monitoring Data for Trihalomethanes in
 Drinking Water

SERIAL OR FILE NO.
 114° WLC
 6280

TO:
 Commanding General
 Marine Corps Base
 Camp Lejeune, NC 28542
 ATTN: Assistant Chief of Staff
 for Facilities

REFERENCE

ENCLOSURE
 See remarks below

VIA: _____ ENDORSEMENT ON _____

FORWARDED RETURNED FOLLOW-UP, OR TRACER REQUEST SUBMIT CERTIFY MAIL FILE

GENERAL ADMINISTRATION	CONTRACT ADMINISTRATION	PERSONNEL
FOR APPROPRIATE ACTION	NAME & LOCATION OF SUPPLIER OF SUBJECT ITEMS	REPORTED TO THIS COMMAND:
UNDER YOUR COGNIZANCE	SUBCONTRACT NO. OF SUBJECT ITEM	
<input checked="" type="checkbox"/> INFORMATION	APPROPRIATION SYMBOL, SUBHEAD, AND CHARGEABLE ACTIVITY	DETACHED FROM THIS COMMAND
APPROVAL RECOMMENDED <input type="checkbox"/> YES <input type="checkbox"/> NO	SHIPPING AT GOVERNMENT EXPENSE <input type="checkbox"/> YES <input type="checkbox"/> NO	OTHER
<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED	A CERTIFICATE, VICE BILL OF LADING	CLW
COMMENT AND/OR CONCURRENCE	COPIES OF CHANGE ORDERS, AMENDMENT OR MODIFICATION	0000005739
CONCUR	CHANGE NOTICE TO SUPPLIER	
LOANED, RETURN BY:	STATUS OF MATERIAL ON PURCHASE DOCUMENT	
SIGN RECEIPT & RETURN		
REPLY TO THE ABOVE BY:		

REFERENCE NOT RECEIVED	REMARKS (Continue on reverse) Encl: (1) TTHM Surveillance Report Form - Hadri Point (2) TTHM Surveillance Report Form - MCA New River (3) TTHM Surveillance Report Form - Rifle Range
SUBJECT DOCUMENT FORWARDED TO:	
SUBJECT DOCUMENT RETURNED FOR:	
SUBJECT DOCUMENT HAS BEEN REQUESTED, AND WILL BE FORWARDED WHEN RECEIVED	
COPY OF THIS CORRESPONDENCE WITH YOUR REPLY	
ENCLOSURE NOT RECEIVED	
ENCLOSURE FORWARDED AS REQUESTED	
ENCLOSURE RETURNED FOR CORRECTION AS INDICATED	
CORRECTED ENCLOSURE AS REQUESTED	
REMOVE FROM DISTRIBUTION LIST	
REDUCE DISTRIBUTION AMOUNT TO:	SIGNATURE & TITLE Wallace Carter, Environmental Engineer

COPY TO:

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

MW

TTHM SURVEILLANCE REPORT FORM

Installation CAMP LEJEUNE - HADIVOT PT.

Date Collected 21 AUG 81 AM

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CHBr ₃	TTHM
WTP 20	521	27.8	INTERFERENCE	3.2	0.1	31 +
NH-1	522	38.2	ON	3.3	0.2	42 +
1202	523	29.3	THIS	2.9	0.1	32 +
65	524	27.7	PEAK	3.2	0.1	31 +
530	525	32.2	↓	3.4	0.1	36 +
Reference OBS						
True						

Date Received 24 AUG 81

Date Analyzed 4 DEC 81

Remarks:

William C Neal

WILLIAM C. NEAL, JR.
Chief, Laboratory Services

CLW

000005740

TTHM SURVEILLANCE REPORT FORM

Installation MCAS - NEW RIVER

Date Collected 19 AUG 81 PM

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CHBr ₃	TTHM
WTP 110	516	SEPTUM INVERTED				—
6-520	517	42.5	33.3	40.7	37.9	154
4025	518	SEPTUM INVERTED				—
710	519	45.3	31.9	38.7	20.1	116
2800	520	48.6	33.4	41.1	24.6	148
Reference OBS						
True						

Date Received 24 AUG 81

Date Analyzed 7 DEC 81

Remarks:

William C. Neal, Jr.
 WILLIAM C. NEAL, JR.
 Chief, Laboratory Services

CLW

000005741

TTHM SURVEILLANCE REPORT FORM

Installation CAMP LE JEUNE - RIFLE RANGE

Date Collected 20 AUG 81

Source	Sample Number	CHCl ₃	CHCl ₂ Br	CHClBr ₂	CHBr ₃	TTHM
P-Cl ₂ WTP	466	7.4	20.1	0.2	20.1	8
A-Cl ₂ WTP	467	50.4	27.4	19.6	2.3	100
6	468	48.9	27.5	20.7	2.5	100
10	469	46.7	26.9	21.6	2.3	98
92	470	48.3	27.2	20.1	2.0	98
Reference OBS						
True						

Date Received 24 AUG 81

Date Analyzed 7 DEC 81

Remarks:

William C. Neal, Jr.

WILLIAM C. NEAL, JR.
Chief, Laboratory Services

CLW

000005742