

TEST WELLS

PARAMETER	HAGNOT POINT 2	MONTFORD POINT 3	TABAWA TERRACE 4	ONELOW BEACH 5	COURTHOUSE BAY	RIFLE RANGE	HOLCOMB BLVD	NEW RIVER
PH	7.9	7.9	8.3	8.2				
PENOLTHALEIN ALKALINITY	0	0	0	0				
METHYL ORANGE ALKALINITY	140	184	120	90				
CARBONATES AS CaCO ₃	0	0	0	0				
BICARBONATES AS CaCO ₃	140	184	120	90				
ORIDES AS Cl	10	2	2	2				
HARDNESS AS CaCO ₃	150	156	54	94				
IRON AS Fe	4.20	5.00	1.64	2.60				
FLUORIDE	0.15	0.34	1.25	0.28				
CHLORINE RESIDUAL								
TURBIDITY	23.0	25.0	29.0	30.0				
TOTAL PHOSPHATE								
ORTHO PHOSPHATE								
META PHOSPHATE								
STABILITY								
REMARKS								

DATE COLLECTED
7/10/84

CLW
000005829

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

H. J. Swana

DATE OF ANALYSIS

7/10/84

CHEMICAL ANALYSIS — WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 3-82)

2
3

Test Wells 4

DATE COLLECTED
7/19/84

PARAMETER	TRINITY POINT	MONTGOMERY POINT	TRAVIVA TERRACE	ONTSROW BEACH	COURTHOUSE BAY	RIFLE RANGE	HOLCOMB BLVD	NEW RIVER
PH	7.9	7.9	8.3	8.2				
PENOLTHALEIN ALKALINITY	0	0	0	0				
METHYL ORANGE ALKALINITY	140	184	120	90				
CARBONATES AS CaCO ₃	0	0	0	0				
BICARBONATES AS CaCO ₃	140	184	120	90				
OXIDES AS Cl	10	2	2	2				
HARDNESS AS CaCO ₃	150	156	54	94				
IRON AS Fe	4.20	5.10	1.64	2.60				
FLUORIDE	0.15	0.34	1.25	0.28				
CHLORINE RESIDUAL								
TURBIDITY	23.0	25.0	29.0	30.0				
TOTAL PHOSPHATE								
ORTHO PHOSPHATE								
META PHOSPHATE								
STABILITY								
REMARKS								

CLW
0000005830

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

DATE OF ANALYSIS

7/19/84