

Memorandum

11332/5

DATE: 20 August 1985
FROM: Physical Science Tech, Water Quality Control Lab
TO: Supervisory Chemist, Water Quality Control Lab

SUBJ: OBSERVATIONS MADE DURING TEST WELL SAMPLING

1. The numerous times I have sampled the new test wells on the Brewster Blvd area, I have observed that the drillers blow air down the well with a gas powered air compressor.
2. The head is always blown off the well and flushing takes place for about five minutes before the sample is taken.
3. The air compressor used seems to be the same one everytime (rental) and the hosing is probably the same also.


GAINES HUNEYCUTT

CLW

000005887