

CHEMICAL ANALYSIS - WATER TREATMENT PLANTS
 MCBCL 11330/3 (REV. 6-84)

TEST RESULTS
 TU-2 TU-3 TU-4 TU-5

DATE COLLECTED 1-13-86
 DATE OF ANALYSIS 1-17-86

FILE 1133Z

PARAMETER	HADNOT POINT	GAMP JOHNSON	TATAYVA TERRACE	GANSTOW BEACH	COURTHOUSE BAY	RIFLE RANGE	HOLCOMB BLVD	NEW RIVER
PH	8.0	8.0	8.8	8.0				
PHENOLTHALEIN ALKALINITY	0	0	4	0				
METHYL ORANGE ALKALINITY	150	184	142	84				
CARBONATES AS CaCO ₃	0	0	8	0				
BICARBONATES AS CaCO ₃	150	184	134	84				
CHLORIDES AS Cl	6	8	8	8				
HARDNESS AS CaCO ₃	154	158	82	82				
IRON AS Fe	7.52	10.00	3.88	8.80				
FLUORIDE	0.19	0.45	0.46	0.33				
CHLORINE RESIDUAL								
TURBIDITY	33.2	22.2	6.1	40.7				
TOTAL PHOSPHATE								
THO PHOSPHATE								
META PHOSPHATE								
STABILITY								

REMARKS
 * 1000 SAMPLES ROAD 1-24-86 DUKOTER (X4)

CLW
 0000005906
 CLW
 0000005906

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

169 Lawrence

COPY TO:
 UTIL DIR
 WATER TREATMENT
 PMU
 MCAS PMU
 NREAD
 FILE

TEST WELLS

CHEMICAL ANALYSIS - WATER TREATMENT PLANTS
 MWBL 11390/3 (REV. 6-84) TW 2 TW 3 TW 4 TW 5
 DATE COLLECTED 1-13-86
 DATE OF ANALYSIS 1-14-86

PARAMETER	HANCOCK POINT	GAMP JOHNSON	FARWATER TERRACE	CONSISTENT BEACH	COURTHOUSE BAY	RIFLE RANGE	HOLCOMB BLVD	NEW RIVER
PH	8.0	8.0	8.8	8.0				
PHENOLTHALEIN ALKALINITY	0	0	4	0				
METHYL ORANGE ALKALINITY	150	184	142	84				
CARBONATES AS CaCO ₃	0	0	8	0				
BICARBONATES CaCO ₃	150	184	134	84				
CHLORIDES AS Cl	6	8	8	8				
HARDNESS AS CaCO ₃	154	150	82	82				
IRON AS Fe	7.52	10.00	3.88	8.80				
FLUORIDE	0.19	0.45	0.46	0.33				
CHLORINE RESIDUAL								
TURBIDITY	33.2	22.2	6.1	40.7				
TOTAL PHOSPHATE								
THO PHOSPHATE								
META PHOSPHATE								
STABILITY								

* 1000 SAMPLES DILUTION (X4)

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

LABORATORY ANALYSIS BY

CLW

0000005907

COPY TO:

- UTIL DIR
- WATER TREATMENT

- PMU
- MCAS PMU
- NREAD
- FILE