

SUMMARY OF TRIHALOMETHANE ANALYSIS

| Sample #'s | System | Averages (Units mg/l, Limit=0.10 mg/l) | | | Compliance** |
|------------|----------------|--|-------------|-------------------------|--------------|
| | | June | April & May | Running Average(2 Qtr*) | |
| 124-128 | Tarawa Terrace | 0.02 | 0.01 | 0.02 | yes |
| 130-134 | Montford Point | 0.01 | 0.01 | 0.01 | yes |
| 135-139 | New River | 0.10 | 0.09 | 0.10 | yes |
| 140-144 | Holcomb Blvd | 0.03 | 0.04 | 0.04 | yes |
| 145-149 | Rifle Range | 0.07 | 0.05 | 0.06 | yes |
| 150-154 | Courthouse Bay | 0.05 | 0.05 | 0.05 | yes |
| 155-159 | Onslow Beach | 0.07 | 0.05 | 0.06 | yes |
| 160-164 | Hadnot Point | 0.02 | 0.04 | 0.03 | yes |

*-According to the Trihalomethane regulation date, the quarters run as follows: December-February, March-May, June-August, and September-November.

F

**-Compliance is actually determined from the running annual(4 Qtr) average.

CLW

0000006123