

WATER SYSTEM: CHAMP JOHNSON

DATE	WATER TREATMENT PLANT Bldg M-178				STEAM PLANT Bldg M-625				BEANERY CLINIC Bldg M-128				SEWAGE PLANT Bldg M-136				BOD Bldg M-213				AVERAGE								
	Chl ₂	Chl ₂ - turb ₂	Chl ₂ - turb ₃	THM	Chl ₂	Chl ₂ - turb ₂	Chl ₂ - turb ₃	THM	Chl ₂	Chl ₂ - turb ₂	Chl ₂ - turb ₃	THM	Chl ₂	Chl ₂ - turb ₂	Chl ₂ - turb ₃	THM	Chl ₂	Chl ₂ - turb ₂	Chl ₂ - turb ₃	THM		Non	Cl ₂						
August 1983	2	3	3	<1	8	1	<1	<1	<1	1	3	3	3	4	<1	10	3	3	3	<1	9	2	3	3	<1	8			

* HOLDING TANKS BETWEEN COLLECTION AND ANALYSIS EXCEEDED 14 DAYS
 (RED SHADOWED BOXES CONTAIN VALUES EXCEEDING THE 100 PPH (0.1 mg/l) LIMIT)

WATER SYSTEM: MONTFORD POINT (Camp Johnson)

DATE	WATER TREATMENT PLANT Bldg. M-178			Bldg. M-625 STEAM PLANT			Bldg. M-123 BRANCH CLINIC			Bldg. M-136 SEWAGE TREAT			Bldg. M-213 BOQ			AVERAGE				
	CHL	CHL/B	THM	CHL	CHL/B	THM	CHL	CHL/B	THM	CHL	CHL/B	THM	CHL	CHL/B	THM	mg/l	mg/l			
APRIL 1982	3	4	2	<1	9	2	<1	<1	2	3	4	2	<1	9	4	4	2	<1	10	7.8
MAY 1982	2	3	2	1	8	<1	<1	<1	<1	7	3	2	<1	7	3	2	4	10	6.2	7.0
JUNE 1982	3	3	3	<1	9	3	<1	<1	4	2	4	2	<1	7	3	4	3	10	6.2	7.2
JULY 1982	1	3	3	1	8	<1	<1	<1	3	3	2	1	<1	8	3	4	3	10	7.6	7.0
AUGUST 1982	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	7	5.8
SEPTEMBER 1982	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	1	5.8
OCTOBER 1982	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	1	5.8
NOVEMBER 1982	3	3	3	<1	9	4	2	2	<1	8	2	3	<1	8	3	3	3	9	8.6	8.6
DECEMBER 1982	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	9	8.6
JANUARY 1983	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	9	8.6
FEBRUARY 1983	1	3	3	<1	7	2	3	3	<1	8	NOT COLLECTED	3	<1	8	3	3	2	5	6.3	6.3
MARCH 1983	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	5	6.3
APRIL 1983	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	5	6.3
MAY 1983	1	3	3	<1	7	1	2	2	<1	5	2	3	1	11	2	3	3	1	9	7
JUNE 1983	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	9	7
JULY 1983	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	No	9	7

* HOLDING TIME BETWEEN COLLECTION AND ANALYSIS EXCEEDED 14 DAYS
 KEEP SAMPLES BOXED COLD FOR UP TO 72 HRS EXCEEDING THE 100PPM (0.1MG/L) LIMIT

CLW

0000006423