

DATE **SAVG 85**

FROM **LANTON COA 1142** FILE NUMBER **6280 1142006**

SUBJECT **THM/VOA AND WASTE OIL TEST RESULTS**

REFERENCE

TO: **MCB CAMP LEBUNK
 BASE MAINTENANCE
 ENVIRONMENTAL AFFAIRS
 DIVISION**

ENCLOSURE
**(1) JTC REPORTS #54
 AND #108 (RECD
 SAVG 85)**

This form may be used in a window envelope.

VIA _____ Endorsement on _____

FORWARDED RETURNED FOLLOW-UP REQUEST ADVISE SUBMIT

X	MESSAGE	X	MESSAGE	X	MESSAGE
<input checked="" type="checkbox"/>	FOR APPROPRIATE ACTION		SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO YOUR OFFICE AS A MATTER UNDER YOUR JURISDICTION.		CERTIFY ENCLOSURE _____ AS TO RECEIPT AND ACCEPTANCE OF MATERIAL AND FORWARD TO _____
	FOR INFORMATION OR CERTIFICATION AND/OR FILE.		SUBJECT DOCUMENTS WAS/WERE APPROVED _____ AND FORWARDED TO YOU.		_____ COPIES OF SUBJECT CHANGE ORDER AMENDMENT OR MODIFICATION
	<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED		_____ COPY(IES) OF THIS CORRESPONDENCE WITH YOUR REPLY.		CHANGE NOTICE TO THE SUPPLIER
	APPROVAL <input type="checkbox"/> IS <input type="checkbox"/> IS NOT RECOMMENDED		ENCLOSURE(S) _____ IS/ARE FORWARDED AS REQUESTED BY REFERENCE _____		_____ COPIES OF APPLICABLE PLANS AND/OR SPECIFICATIONS.
	CONCURRING IN RECOMMENDATIONS MADE IN THE BASIC CORRESPONDENCE.		ENCLOSURE(S) IS/ARE RETURNED FOR CORRECTION AS INDICATED.		FOR PLAN ACTION AS INDICATED
	COMMENTS AND/OR RECOMMENDATIONS.		CORRECTED ENCLOSURE(S) AS REQUESTED		CLASSIFICATIONS OF DEFECTS FOR SUBJECT ITEMS
	MAILING LIST ACTION		SUBJECT PERSON'S ATTENTION SHOULD BE INVITED TO THIS MATTER		CONFIRMATION THAT INSPECTION OR SOURCE INSPECTION IS NOT REQUIRED
	FOR ASSIGNMENT OF BUREAU FILE NUMBER(S)		SUBJECT PERSON(S) REPORTED TO THIS COMMAND _____		INSPECTION UNDER THE SUBJECT SUBCONTRACT IS NOT REQUIRED
	ON A LOAN BASIS RETURN BY _____		SUBJECT PERSON(S) COMPLETED HIS/THEIR DUTY AND WAS/WERE DETACHED FROM THIS COMMAND _____		_____ COPIES OF SUBJECT PURCHASE DOCUMENT. IF SOURCE INSPECTION OR PROGRESSING IS REQUIRED
	SIGN ORIGINAL RECEIPT AND RETURN TO THIS OFFICE.		NAME AND LOCATION OF SUPPLIER OF SUBJECT ITEMS.		STATUS OF MATERIAL ON SUBJECT PURCHASE DOCUMENT
	SUBJECT FILES, WHICH ARE LOCATED IN BOX NO. _____ SHIPMENT NO. _____		SUBCONTRACT NUMBER FOR SUBJECT ITEM		CLEARANCE AS INDICATED IN BASIC CORRESPONDENCE VERIFIED. NO REPLY UNLESS NEGATIVE.
	REPLY TO THE ABOVE REFERENCE(S) BY _____		SUBJECT PURCHASE DOCUMENT HAS BEEN REQUESTED AND WILL BE FORWARDED WHEN RECEIVED.		VERIFICATION OF NEED-TO-KNOW FOR VISIT PERSONNEL CLEARANCES VERIFIED.
	_____ COPY(IES) OF REFERENCE DESCRIBED ABOVE WAS/WERE NOT RECEIVED.		ENDORSEMENT _____ OF SUBJECT SUBCONTRACT IS BEING DELAYED PENDING RECEIPT OF BASIC PURCHASE DOCUMENT.		
	SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO _____		APPROPRIATION SYMBOL SUBHEAD AND CHARGEABLE ACTIVITY		
	SUBJECT DOCUMENT(S) IS/ARE WAS/WERE RETURNED FOR _____		WHETHER SUBJECT ITEMS ARE TO BE COMMERCIALY SHIPPED OR AT GOVERNMENT EXPENSE		
			A CERTIFICATE IN LIEU OF SUBJECT BILL OF LADING WHICH HAS BEEN LOST.		SEE REMARKS ON THE REVERSE SIDE.

COPY TO **114 (w/ #108), 1142, 114 PBI (w/ #54), 1145**

SIGNATURE

CLW

0000005102

REPORT # 108
LABORATORY ANALYSIS ON
NAVAL SAMPLES
(A/E CONTRACT N62470-84-B-6932)
JTC REPORT # 85-310

PREPARED FOR:
DEPARTMENT OF THE NAVY
ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VA 23511

PREPARED BY:
JTC ENVIRONMENTAL CONSULTANTS, INC.
4 RESEARCH PLACE, SUITE L-10
ROCKVILLE, MARYLAND 20850
AUGUST 2, 1985

Ann E Rosecrance
Ann E. Rosecrance
Laboratory Director

CLW
0000005103

CLW

000005104

JTC Environmental Consultants, Inc.

Date 8-2-85 Report No. 108 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-310 Table 1 Date of Sample Receipt 8-1-85

Campejeune

NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER						
		THM						
2800 0949 7/31	12-1341	see attached sheet						
G-520 1010 7/31	12-1342	"						
AS-4025 0930 7/31	12-1343	"						
710 1000 7/31	12-1345	"						

Note: AS-110 (12-1344) was broken in transit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1341 PROJECT NO. NF-12
CLIENT SAMPLE ID 2800 7/31/85 DATE RECEIVED 8/1/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	20 N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	17 N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichloro fluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	29 N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	8* N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

CLW
0000005106
*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1342 PROJECT NO. NF-12
CLIENT SAMPLE ID G-520 7/31/85 DATE RECEIVED 8/1/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	32 N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	20 N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	36 N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D. 10	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005107

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1343 PROJECT NO. NF-12
CLIENT SAMPLE ID AS-4025 7/31/85 DATE RECEIVED 8/1/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D. 13
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	N.D. 14
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	N.D. 24
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	N.D. 7*	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

0000005108

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1345 PROJECT NO. NF-12
CLIENT SAMPLE ID 710 7/31/85 DATE RECEIVED 8/1/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	15 N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	15 N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	26 N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	8* N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005109

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1346 PROJECT NO. NF-12
 CLIENT SAMPLE ID TT 7/31/85 DATE RECEIVED 8/1/85
 METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	8* N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	5* N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	12 N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	3* N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005110

N.D. = NOT DETECTED
 N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit



JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1347 PROJECT NO. NF-12
CLIENT SAMPLE ID HP 7/31/85 DATE RECEIVED 8/1/85
METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT	PARAMETER	RESULT
	ug/lit		ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloro- pylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloro- ethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromo- methane	7* N.D.
14V 1,1,2-trichloro- ethane	N.D.	49V trichlorofluoro- methane	N.D.
15V 1,1,2,2-tetra- chloroethane	N.D.	50V dichlorodifluoro- methane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	5* N.D.
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	13 N.D.	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloro- ethylene	N.D.	88V vinyl chloride	N.D.

CLW

000005111

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit