

ROUTINE REPLY, ENDORSEMENT, TRANSMITTAL OR INFORMATION SHEET

OPNAV 5216/158 (Rev. 7-78)
SN 0107-LF-052-1691

A WINDOW ENVELOPE MAY BE USED
Formerly NAVEXOS 3789

DDS

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

FROM (Show telephone number in addition to address)

CANTON COOR 1142 AIV 564-9561

DATE

20 OCT 85

SUBJECT

VOA

SERIAL OR FILE NO.

6280 1142A6

TO:

MCB CAMP LAJUNGE
BASE MAINTENANCE
ENVIRONMENTAL AFFAIRS DIVISION

REFERENCE

ENCLOSURE

(1) JTZ REPORT #149
(Rec'd 20 OCT 85)

VIA:

ENDORSEMENT ON

FORWARDED RETURNED FOLLOW-UP, OR TRACER REQUEST SUBMIT CERTIFY MAIL FILE

GENERAL ADMINISTRATION		CONTRACT ADMINISTRATION		PERSONNEL	
<input checked="" type="checkbox"/> FOR APPROPRIATE ACTION UNDER YOUR COGNIZANCE INFORMATION		NAME & LOCATION OF SUPPLIER OF SUBJECT ITEMS		REPORTED TO THIS COMMAND:	
APPROVAL RECOMMENDED <input type="checkbox"/> YES <input type="checkbox"/> NO		SUBCONTRACT NO. OF SUBJECT ITEM		DETACHED FROM THIS COMMAND	
<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED		APPROPRIATION SYMBOL, SUBHEAD, AND CHARGEABLE ACTIVITY		OTHER	
COMMENT AND/OR CONCURRENCE		SHIPPING AT GOVERNMENT EXPENSE <input type="checkbox"/> YES <input type="checkbox"/> NO			
CONCUR		A CERTIFICATE, VICE BILL OF LADING			
LOANED, RETURN BY:		COPIES OF CHANGE ORDERS, AMENDMENT OR MODIFICATION			
SIGN RECEIPT & RETURN		CHANGE NOTICE TO SUPPLIER			
REPLY TO THE ABOVE BY:		STATUS OF MATERIAL ON PURCHASE DOCUMENT			
REFERENCE NOT RECEIVED		REMARKS (Continue on reverse)			
SUBJECT DOCUMENT FORWARDED TO:					
SUBJECT DOCUMENT RETURNED FOR:					
SUBJECT DOCUMENT HAS BEEN REQUESTED, AND WILL BE FORWARDED WHEN RECEIVED					
COPY OF THIS CORRESPONDENCE WITH YOUR REPLY					
ENCLOSURE NOT RECEIVED					
ENCLOSURE FORWARDED AS REQUESTED					
ENCLOSURE RETURNED FOR CORRECTION AS INDICATED					
CORRECTED ENCLOSURE AS REQUESTED					
REMOVE FROM DISTRIBUTION LIST					
REDUCE DISTRIBUTION AMOUNT TO:					
SIGNATURE & TITLE		<i>David ... 1142</i>			

CLW
0000005839

COPY TO:

114, 1142, 1145

CLASSIFICATION (UNCLASSIFIED when detached from enclosures, unless otherwise indicated)

REPORT # 149
LABORATORY ANALYSIS ON
NAVAL SAMPLES
(A/E CONTRACT N62470-84-B-6932)
JTC REPORT # 85-400

PREPARED FOR:
DEPARTMENT OF THE NAVY
ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
. NORFOLK, VA 23511

PREPARED BY:
JTC ENVIRONMENTAL CONSULTANTS, INC.
4 RESEARCH PLACE, SUITE L-10
ROCKVILLE, MARYLAND 20850

SEPTEMBER 30, 1985

CLW
0000005840

Ann E Rosecrance
Ann E. Rosecrance
Laboratory Director

~~CLW~~
~~0000005840~~


Location: Camp Lejeune Date of Receipt: 9-24-85 Turnaround: 2 weeks

Date: 9/30/85 Report No. 149 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-400 Table 1

NAVY SAMPLE ID		JTC SAMPLE ID	ANALYSIS PARAMETER							
HP Water Plant 9/23/85 0805		12-1551	VOA							
PI Water Plant 9/23/85 0840		12-1552	See attached sheet							
Test Well 12 85-95' 9/20/85		12-1553	"							
0000005841										

CLW

J
T
C

Environmental Consultants, Inc.

PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1551 PROJECT NO. NF-12 #149
CLIENT SAMPLE # HP Water Plant DATE RECEIVED 9/24/85
METHOD NO. 624 DETECTION LIMIT 10 ug/L


PARAMETER	RESULT	PARAMETER	RESULT
	ug/L		ug/L
acrolein	ND	1,2-dichloropropane	ND
acrylonitrile	ND	1,3-dichloropropylene	ND
benzene	ND	ethylbenzene	ND
carbon tetrachloride	ND	methylene chloride	ND
chlorobenzene	ND	methyl chloride	ND
1,2-dichloroethane	ND	methyl bromide	ND
1,1,1-trichloroethane	ND	bromoform	ND
1,1-dichloroethane	ND	dichlorobromomethane	13 ND
1,1,2-trichloroethane	ND	trichlorofluoromethane	ND
1,1,2,2-tetrachloroethane	ND	dichlorodifluoromethane	ND
chloroethane	ND	chlorodibromomethane	8* ND
2-chloroethylvinylether	ND	tetrachloroethylene	ND
chloroform	16 ND	toluene	ND
1,1-dichloroethylene	ND	trichloroethylene	ND
1,2-trans-dichloroethylene	ND	vinyl chloride	ND
		xylenes	ND

CLW

ND = NOT DETECTED

* = BELOW DETECTION LIMIT

000005842



J
T
C Environmental Consultants, Inc.

PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1552 PROJECT NO. NF-12 #149
CLIENT SAMPLE # TT Water Plant DATE RECEIVED 9/24/85
METHOD NO. 624 DETECTION LIMIT 10 ug/L


PARAMETER	RESULT ug/L	PARAMETER	RESULT ug/L
acrolein	ND	1,2-dichloropropane	ND
acrylonitrile	ND	1,3-dichloropropylene	ND
benzene	ND	ethylbenzene	ND
carbon tetrachloride	ND	methylene chloride	ND
chlorobenzene	ND	methyl chloride	ND
1,2-dichloroethane	ND	methyl bromide	ND
1,1,1-trichloroethane	ND	bromoform	7* ND
1,1-dichloroethane	ND	dichlorobromomethane	6* ND
1,1,2-trichloroethane	ND	trichlorofluoromethane	ND
1,1,2,2-tetrachloroethane	ND	dichlorodifluoromethane	ND
chloroethane	ND	chlorodibromomethane	10 ND
2-chloroethylvinylether	ND	tetrachloroethylene	ND
chloroform	3* ND	toluene	ND
1,1-dichloroethylene	ND	trichloroethylene	ND
1,2-trans-dichloroethylene	ND	vinyl chloride	ND
		xylenes	ND

ND = NOT DETECTED

* = BELOW DETECTION LIMIT

CLW

000005843

J
T
C

Environmental Consultants, Inc.

PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1553 PROJECT NO. NF-12 #149
CLIENT SAMPLE # Test well #12 DATE RECEIVED 9/24/85
METHOD NO. 624 DETECTION LIMIT 10 ug/L

PARAMETER	RESULT ug/L	PARAMETER	RESULT ug/L*
acrolein	ND	1,2-dichloropropane	ND
acrylonitrile	ND	1,3-dichloropropylene	ND
benzene	ND	ethylbenzene	2* ND
carbon tetrachloride	ND	methylene chloride	ND
chlorobenzene	ND	methyl chloride	ND
1,2-dichloroethane	ND	methyl bromide	ND
1,1,1-trichloroethane	ND	bromoform	ND
1,1-dichloroethane	ND	dichlorobromomethane	ND
1,1,2-trichloroethane	ND	trichlorofluoromethane	ND
1,1,2,2-tetrachloroethane	ND	dichlorodifluoromethane	ND
chloroethane	ND	chlorodibromomethane	ND
2-chloroethylvinylether	ND	tetrachloroethylene	ND
chloroform	ND	toluene	4* ND
1,1-dichloroethylene	ND	trichloroethylene	ND
1,2-trans-dichloroethylene	ND	vinyl chloride	ND
		xylenes	12 ND

ND = NOT DETECTED

* = BELOW DETECTION LIMIT

CLW

000005844