



## North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

Commanding General  
US Marine Corps Base  
Camp Lejeune, NC 28542

ATTN: Utilities Director  
G. S. Johnson, Jr.

Dear Sir:

I visited the potable water treatment facilities aboard USMCB Camp Lejeune on 10 and 11 April 1986. I was accompanied during this visit by Mr. B. M. Frazelle, Jr. (Water Treatment Operator Foreman). The purpose of this visit was to update our files and records concerning the facility operations, treatment capacities, and construction work in progress as well as offer any suggestions for improvements in the process or daily operation and maintenance at the treatment facilities.

The routine plant operation and equipment maintenance are well organized and carried out. I was very pleased with the expansion and upgrading work recently completed or now in progress at several facilities.

We discussed several specific plant situations including: (1) A light film on the water surface at the filters in the Holcomb Boulevard facility may be from oil lubricated well pumps. (2) The maintenance level at the Tarawa Terrace and Camp Johnson facilities has dropped below the others. This is understandable, however, considering these are to be abandoned when the Holcomb Boulevard project is completed (estimated late 1986). (3) The water flow pattern at the Onslow Beach system is different from other facilities utilizing similar treatment. Normally, water is pumped from the wells through filters then through the ion exchange softeners, not divided. Additionally, filter backwash water is usually from the treated water system, not untreated well water.

We also discussed several items which may be applicable to more than one facility. These include: (1) The filters and softeners should be inspected annually for media loss and condition as well as any structural or operational abnormalities. (2) Covers for the brine (NaCl) day tanks will reduce some of the problems with surface corrosion. Installation and operation of dehumidifiers will also help this problem. (3) The existing treatment process consisting of aeration, lime addition, sedimentation, filtration (sand media), ion exchange (softening), chlorination, and phosphate (at three plants) may be altered to reduce chemical costs while maintaining acceptable quality. An in-plant or laboratory trial of the process may prove effective, depending on more detailed water quality analysis

Commanding General  
Page 2  
April 16, 1986


and study. (4) I noticed several open electrical service panels. A standing policy should be established to close or secure these at the end of the work or shift change, especially in the water plant areas. (5) Many water systems utilizing dry feeders for fluoride prefer sodium silicofluoride (due to its cost) instead of sodium fluoride (dissolves only to 4% solution). (6) Records of operations (including total water treated, filter and softener operations, chemical feed and dosage rates, etc.) should be reported monthly for each facility to our office in Raleigh.

I understand that planning is in progress for the development of private operations contracts for the water treatment facilities. Our office, in cooperation with the NC Attorney General's office, would like to review the final contract proposal to determine the operation's responsibilities as well as the system's liabilities.

As always, I appreciate the cooperation and attitude of the Base towards the State's Water Supply Branch and regulations.

If you have any questions or wish to discuss these comments further, please contact me.

Sincerely,



J. Fred Hill  
Water Plant Consultant  
Water Supply Branch  
Environmental Health Section

bgb

Enclosures

cc: C. E. Rundgren  
M. P. Bell



North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

MEMORANDUM

TO: Charles E. Rundgren, Chairman  
N.C. Water Treatment Facility Operators Board of Certification

FROM: J. Fred Hill  
Water Plant Consultant *JFH*

SUBJECT: Water Treatment Plant Ratings  
USMC Base Camp Lejeune

Attached are the classification rating forms with the modification for lime softening with spiractors that we discussed.

The eight systems surveyed are directed, managed, and operated through a common administration and responsible operator in charge (Byron M. Frazelle, "A" certification).

I recommend the system be classified to an "A" rating based on the management organization and the diversified treatment techniques involved.

If you have any questions, please let me know.

bgb

Attachments

USMC BASE  
CAMP LEJEUNE  
MANAGEMENT

Operations

LtCol. W. M. Rice  
Base Maintenance Officer

Fred Cone  
Asst. BMO

G. S. Johnson, Jr.  
Utilities Director

David Southerland  
Util. General Foreman

Willard Price  
General Foreman

B. M. Frazelle (Mac)  
WTP Operator Foreman

Monitoring & Surveillance

Natural Resources and Environmental  
Affairs Division

Julian Wooten, Director  
Danny Sharpe, Supervisory Ecologist  
Elizabeth Metz, Supv. Chemist

## US MARINE CORPS BASE

Camp Lejeune, NC

WTP Operators

<u>Name</u>	<u>Title</u>	<u>Certification</u>
Adkins, James M.	Water Treatment Plant Operator	C-Well
Barber, Elbert F.	Water Treatment Plant Operator	C
Brown, Leland R.	Industrial Equipment Repairer	C-Well
Campbell, Emery G.	Water Treatment Plant Operator	C
Cannon, Fred J.	Water Treatment Plant Operator	C
Huneycutt, Gaines B.	Water Plant Operator	C
Collins, Philip R.	Water Treatment Plant Operator	C
Duncan, Freddy	Water Treatment Plant Operator	B
Dunlap, James	Water Plant Operator	O
Ellis, Donald R.	Water Treatment Plant Operator Leader	C
Frazelle, Byron M.	Water Treatment Plant Operator Foreman	A
Hardison, Rufus C.	Water Treatment Plant Operator	C
Hartsoe, Joel R.	Water Treatment Plant Operator Leader	B-Well
Herring, L.	Water Plant Operator	O
Hill, Daniel E., Jr.	Water Treatment Plant Operator Leader	B-Well
Holland, Larry W.	Water Treatment Plant Operator Leader	B-Well
Phillips, Major	Water Treatment Plant Operator Helper	O
James, Nathaniel L.	Water Plant Operator	O
Kelly, Calvin D., Jr.	Water Treatment Plant Operator	C
Kolde, Sally	Clerk Typist	O
Lee, Jerry J.	Water Treatment Plant Operator	C
Marhelko, Michael J.	Water Treatment Plant Operator	C
Miller, Stanley L.	Water Treatment Plant Operator Leader	B
Milton, George D.	Water Treatment Plant Operator	C
Morton, Billie L.	Water Treatment Plant Operator	B
Mundt, Berton L.	Water Treatment Plant Operator	C
Odum, Cobrett G.	Water Treatment Plant Operator	C
Parker, Leon S.	Water Treatment Plant Operator	C-Well
Pehowic, Stanley A.	Water Treatment Plant Operator Leader	B
Petersen, Larry G.	Water Treatment Plant Operator	C-Well
Christensen, Nancy	Water Treatment Plant Operator Helper	O
Price, W. R.	Utilities Systems Plant General Foreman	B
Reiff, Howard F.	Water Treatment Plant Operator	C
Rich, Melvin P.	Industrial Equipment Mechanic	C
Riggs, Alvin T.	Water Treatment Plant Operator	C
Riggs, Joseph E.	Water Treatment Plant Operator	C
Smallwood, Scottie	Water Treatment Plant Operator	C
Stone, Tally	Water Treatment Plant Operator	C
Sumner, David W.	Industrial Equipment Repairer	C-Well
Sypnier, Richard A.	Water Treatment Plant Operator	C
Thomas, Tommie T.	Industrial Equipment Mechanic	C-Well
Vick, Ronnie C.	Instrument Mechanic	B-Well
Ward, William	Water Plant Operator	O
Wooten, Robert	Water Treatment Plant Operator	C-Well

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC Camp Lejeune - Holcomb Blvd.

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
 Grade

NAME B. M. Fenzelle  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>see list</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	3
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	2
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	
Coagulation <u>SPIRATOR - Lime</u>	10	10
Sedimentation	5	
Filtration	10	10
Disinfection	10	10
Ion Exchange	5	
Adsorption	2	
Chemical Oxidation	2	
Softening	2	2
Stabilization	2	
Fluoridation	10	10
Raw Water Pumping	5	5
Receiving Basin	1	
Finished Water Pumping	5	5
Storage at Plant	1	1
Storage - System	2	2
Pumpage - from attached chart <u>(1,204 mg)</u>	1-50	12
TOTAL POINTS		<u>72</u>

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC-Lejeune HANNOT POINT

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED A

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
 Grade

NAME B. M. Frazelle  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	3
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	2
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	
Coagulation <i>Spirator - Lime</i>	10	10
Sedimentation	5	
Filtration	10	10
Disinfection	10	10
Ion Exchange	5	
Adsorption	2	
Chemical Oxidation	2	
Softening	2	2
Stabilization	2	
Fluoridation	10	10
Raw Water Pumping	5	5
Receiving Basin	1	1
Finished Water Pumping	5	5
Storage at Plant	1	1
Storage - System	2	2
Pumpage - from attached chart	1-50	24
TOTAL POINTS	(3,241 mbs)	85

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC Camp Lejeune - Onslow Beach

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B.W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE - A -  
 Grade

NAME B. M. Frazelle  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>SEE LIST</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	<u>3</u>
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	<u>2</u>
Coagulation	10	
Sedimentation	5	
Filtration	10	<u>10</u>
Disinfection	10	<u>10</u>
Ion Exchange	5	<u>5</u>
Adsorption	2	
Chemical Oxidation	2	
Softening	2	<u>2</u>
Stabilization	2	
Fluoridation	10	
Raw Water Pumping	5	<u>5</u>
Receiving Basin	1	
Finished Water Pumping	5	<u>5</u>
Storage at Plant	1	<u>1</u>
Storage - System	2	<u>2</u>
Pumpage - from attached chart	1-50	<u>2</u>
TOTAL POINTS	<u>(137 mg)</u>	<u>49</u>

DATE 4-10-86



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY 115 MC Camp Lejeune - Quartermaster Bldg

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
 Grade

NAME B. M. Frazelle  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>See list</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	<u>3</u>
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	<u>2</u>
Coagulation	10	
Sedimentation	5	
Filtration	10	<u>10</u>
Disinfection	10	<u>10</u>
Ion Exchange	5	<u>5</u>
Adsorption	2	
Chemical Oxidation	2	
Softening	2	
Stabilization	2	<u>2</u>
Fluoridation	10	
Raw Water Pumping	5	<u>5</u>
Receiving Basin	1	
Finished Water Pumping	5	<u>5</u>
Storage at Plant	1	<u>1</u>
Storage - System	2	<u>2</u>
Pumpage - from attached chart	1-50	<u>5</u>
	(452 mb)	
TOTAL POINTS		<u>52</u>

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC Camp Lejeune - Rifle Range

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
 Grade

NAME B.M. FRACELLE  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>see list</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	3
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	2
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	2
Coagulation	10	
Sedimentation	5	
Filtration	10	10
Disinfection	10	10
Ion Exchange	5	5
Adsorption	2	
Chemical Oxidation	2	
Softening	2	
Stabilization	2	2
Fluoridation	10	
Raw Water Pumping	5	5
Receiving Basin	1	
Finished Water Pumping	5	5
Storage at Plant	1	1
Storage - System	2	2
Pumpage - from attached chart	1-50	3
	(262 mb)	
TOTAL POINTS		50

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY 13117 - 60 - 111111 TAKANK TERZALE

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-2

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
Grade

NAME B. M. Frazelle  
(Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	3
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	3
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation----- <u>Limy - SPIRATOR</u>	10	10
Sedimentation-----	5	
Filtration-----	10	10
Disinfection-----	10	10
Ion Exchange-----	5	
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	2
Stabilization-----	2	
Fluoridation-----	10	10
Raw Water Pumping-----	5	5
Receiving Basin-----	1	
Finished Water Pumping-----	5	5
Storage at Plant-----	1	1
Storage - System-----	2	2
Pumpage - From attached chart-----	1-50	2
TOTAL POINTS		69

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC Camp Johnson

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-10

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE L  
 Grade

NAME B. M. Traylor  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground	3	3
Surface	5	
Surface with Reservoir	6	
Coliform Bacteria less than 1.0 per 100 ml	2	2
Coliform Bacteria 1.0 - 100 per 100 ml	4	
Coliform Bacteria 100 - 1000 per 100 ml	6	
Coliform Bacteria 1000 - 5000 per 100 ml	8	
Coliform Bacteria 5000 - 20000 per 100 ml	12	
Aeration	2	
Coagulation	10	
Sedimentation	5	
Filtration	10	
Disinfection	10	10
Ion Exchange	5	5
Adsorption	2	
Chemical Oxidation	2	
Softening	2	2
Stabilization	2	2
Fluoridation	10	
Raw Water Pumping	5	5
Receiving Basin	1	
Finished Water Pumping	5	5
Storage at Plant	1	1
Storage - System	2	2
Pumpage - from attached chart	1-50	2
TOTAL POINTS	(340 min)	41

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES  
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION  
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC CAMP LEONINE - NEW RIVER AIR STATION

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B.W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A  
 Grade

NAME B.M. Frazelle  
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>SEE ULT</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation----- <u>SPIRATOR - LIME</u>	10	10
Sedimentation-----	5	
Filtration-----	10	10
Disinfection-----	10	10
Ion Exchange-----	5	
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	
Stabilization----- <u>RECARBONATION</u>	2	2 (2)
Fluoridation-----	10	
Raw Water Pumping-----	5	5
Receiving Basin-----	1	
Finished Water Pumping-----	5	5
Storage at Plant-----	1	1
Storage - System-----	2	2
Pumpage - from attached chart-----	1-50	5
TOTAL POINTS-----		57 (6)

DATE 4-10-86

WELL NO. \_\_\_\_\_

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - all wells

Sources of pollution/distance controlled by USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? yes

Properly drained? \_\_\_\_\_ Freeze protection? \_\_\_\_\_

Condition of house OK Locked? yes

3) WELL: Diameter VARIES Type const. GRAVEL Yield (GPM) VARIES Storage at well NO

Properly sealed? \_\_\_\_\_ ~~Properly vented?~~ TOTAL - 7224 gpm

35 wells  
Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? @ WTP

Concrete slab adequate? \_\_\_\_\_ ~~is~~ AUX @ 18 wells

Size of blow-off \_\_\_\_\_ Sample tap available \_\_\_\_\_

4) PUMP: Capacity MAX 450 MIN 105 AVG 350 Type pump VERT TURB (service pumps 1 @ 3000 gpm 3 @ 1500 gpm 2 w/aux pwr)

Height above floor (pump/casing) \_\_\_\_\_ Is pump leaking? \_\_\_\_\_

TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type WET GAS Capacity 50/200 gpd In Service? yes

Spare parts or unit? SPARE UNIT (200 gpd) proper ventilation? yes Gas Mask? AIRPK REPAIR KIT ch2 ALERT

Recommission  
Type PROPANE GAS - SUBMERGED BURNER Condition NEW - 85

Filter(s): Type GRAVITY No. 5 Media SAND-ANTHRACITE

Size 350 # ea Rate (gpm/ft<sup>2</sup>) 2.0 Head loss B/W @ 5 ft.

Type controls NEW Condition GOOD

Comments SURFACE WASH ea. filter

Softeners: Type SPIRATORS No. 5 Media SAND-catalyst

Size HYDRANT LINE (DT) Rate (gpm/ft<sup>2</sup>) 1.0 MGD ea Head loss \_\_\_\_\_

Type controls 1000 # Lime / MG H<sub>2</sub>O Condition \_\_\_\_\_

Comments \_\_\_\_\_

Other treatment (Describe): WET NaF-GRANULOMETRIC (New 85)

Process Wastewater treatment (Describe): NEW - B/W to holding basin - sludge to SAN SWR  
③ SUPNAT. TO RAW WATER

6) REMARKS AND RECOMMENDATIONS \_\_\_\_\_

Maintains pH @ 8.8 for stability

DEPARTMENT OF HUMAN RESOURCES  
DIVISION OF HEALTH SERVICES  
\*WELL INFORMATION\*

WELL NO. \_\_\_\_\_

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - All wells  
Sources of pollution/distance NONE - controlled by USMC  
Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? yes  
Properly drained? yes Freeze protection? yes  
Condition of house OK Locked? yes

3) WELL: Diameter VARIUS Type const. GRAVEL Yield (GPM) VARIUS Storage at well NO  
Properly sealed? \_\_\_\_\_ Properly vented? Total 1300 gpm  
8 wells Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? @ WTP  
Concrete slab adequate? \_\_\_\_\_ Size RW EN? @ 4 wells  
Size of blow-off \_\_\_\_\_ Sample tap available \_\_\_\_\_

4) PUMP: Capacity Min 133 Max 350 Avg 225 Type pump VERT TURBINE (usual)  
Height above floor (pump/casing) \_\_\_\_\_ High serv. pumps  
Is pump recirculating? 2 @ 700 gpm 2 @ 1500 gpm  
(Aux avail on each)

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type WET GAS Capacity 1 @ 50 operated @ 2 @ 100 35ppm In Service? yes

Spare parts or unit? 3 units Proper ventilation? yes Gas Mask? yes; Respirator kit & alert system

Aerator: Type NONE Condition \_\_\_\_\_

Filter(s): Type GRAVITY No. 2 Media RAPID SAND

Size 18 X 20' Rate (gpm/ft<sup>2</sup>) 2.0 usual Head loss -

Type controls ROBERTS- Condition good

Comments all controls & meters OK; surface sweeps in each

Softeners: Type SPIRAATOR No. 2 Media CATALYST (SAND)

Size 700 gpm (2) Rate (gpm/ft<sup>2</sup>) - Head loss -

Type controls HYDRATED LIME - Bulk Condition good

Comments \_\_\_\_\_

Other treatment (Describe): NaF with gravimetric feeder - calibrated ea shift

Process wastewater treatment (Describe): settling pond - disch to can. sur.

6) REMARKS AND RECOMMENDATIONS Oil film on filters may be from oil lubricated pumps - S/B careful. (2) Be careful with NaF (most use Na2SiF6)

WELL NO. \_\_\_\_\_

\*WELL INFORMATION\*

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL WELLS

Sources of pollution/distance CONTROLLED BY USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? YES

Properly drained? \_\_\_\_\_ Freeze protection? \_\_\_\_\_

Condition of house OK Locked? YES

3) WELL: Diameter VARIED Type const. \_\_\_\_\_ Yield (GPM) Varies Storage at well \_\_\_\_\_

Properly sealed? \_\_\_\_\_ Properly vented? \_\_\_\_\_

Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? @ WTP

Concrete slab adequate? \_\_\_\_\_ See HWS ENQ @ 7 wells

Size of blow-off \_\_\_\_\_ Sample tap available YES

26 wells

4) PUMP: Capacity 400 <sup>MAX</sup> 50 <sup>MIN</sup> 164 <sup>Avg</sup> Type pump VERT TURB (HUB DRIVE) 2 @ 1000 gpm  
1 @ 500 gpm

Height above floor (pump/casing) \_\_\_\_\_ Is pump leaking? POOSTERS 2 @ 125 gpm  
2 @ 750 gpm  
3 @ 700 gpm

5) TREATMENT: Is this a central treatment facility? YES (one of eight)

Chlorinator: Type WET GAS (T-CONT) Capacity 1 1/2 @ 200 gpd In Service? YES

Spare parts or unit? SPARE w/200 gpd Proper ventilation? YES See HWS? FIRE PACK REPAIR KIT; ALARMS.

RECARBONATION

Source: Type NATURAL GAS (BURMAGED) Condition OK

Filter(s): Type GRAVITY (NO RATE CONTROLS) 3 ea Media SAND & ANTHRACITE

Size 17' x 23' Rate (gpm/ft<sup>2</sup>) \_\_\_\_\_ Head loss B/D @ 2.5-3.0 OR 48 hrs

Type controls R/W controls only Condition OK @ SURFACE WASH

Comments FILTER RATE CHANGES BASED ON C.O.H. FILTER OPERATES THRU RECARB UNIT

Softeners: Type SPINACTORS No. 2 Media SAND-CATALYST

Size \_\_\_\_\_ Rate (gpm/ft<sup>2</sup>) 1200 gpm ea Head loss \_\_\_\_\_

Type controls USES HYDRATED LIME Condition OK (BUK STORAGE)

Comments LIME SLAKER - SPARE UNIT

Other treatment (Describe): \_\_\_\_\_

Process Wastewater treatment (Describe): TO SAN SWR

6) REMARKS AND RECOMMENDATIONS Aux generator @ WTP



DEPARTMENT OF HUMAN RESOURCES  
 DIVISION OF HEALTH SERVICES  
 \*WELL INFORMATION\*

WELL NO. \_\_\_\_\_

IO NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL wells

Sources of pollution/distance controlled by USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? yes

Properly drained? \_\_\_\_\_ Freeze protection? \_\_\_\_\_

Condition of house OK Locked? yes

3) WELL: Diameter VARIED Type const. GRAVEL Yield (GPM) VARIED Storage at well NO

Properly sealed? \_\_\_\_\_ Properly vented? \_\_\_\_\_

8 wells

Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? @ WTP

Concrete slab adequate? not for 2 wells

Size of blow-off \_\_\_\_\_ Sample tar. available? yes

4) PUMP: Capacity MIN 40 MAX 200 AVG 115 Type VERT TURBS. (2000 gpm pumps - 1250 gpm (w/aux) 1000 gpm 500 gpm)

Height above floor (pump/casing) \_\_\_\_\_ Is pump leaking? \_\_\_\_\_

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type W&T gas (150#) Capacity 10/30 ppd In Service? yes

Spare parts or unit? spare unit (50 ppd) Proper ventilation? yes (a. v. v. AIR PACK, REPAIR KIT, Cl<sub>2</sub> ALERT.)

Aerator: Type NONE Condition \_\_\_\_\_

Filter(s): Type NONE No. \_\_\_\_\_ Media \_\_\_\_\_

Size \_\_\_\_\_ Rate (gpm/ft<sup>2</sup>) \_\_\_\_\_ Head loss \_\_\_\_\_

Type controls \_\_\_\_\_ Condition \_\_\_\_\_

Comments \_\_\_\_\_

Softeners: Type ION EXCHANGE No. 2 Media Na Zeolite

Size 72" Ø Rate (gpm) 180 ea Head loss ± 10

Type controls \_\_\_\_\_ Condition fair (some leaks)

Comments Regr. @ 04816 - Bulk salt tank w/ dry tank inside WTP

Other treatment (Describe): Phosphate - BIF tank pump (2 gal/50 gal H<sub>2</sub>O) (1.0 mg/l ORING POU)

Process wastewater treatment (Describe): discharging to SAN. SWIM.

6) REMARKS AND RECOMMENDATIONS ① valves leaking at softener ② to be replaced w/ Fe/Si

WELL NO. \_\_\_\_\_

\*WELL INFORMATION\*

ID NO.: \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - All wells

Sources of pollution/distance SITES CONTROLLED BY USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? YES

Properly drained? \_\_\_\_\_ Freeze protection? \_\_\_\_\_

Condition of house OK Locked? YES

3) WELL: Diameter 6 INCHES Type const. GRAVEL Yield (GPM) 111 → 236 Storage at well NO

Total 9 Properly sealed? YES Properly vented? \_\_\_\_\_

6 wells Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? \_\_\_\_\_

3 wells (EMER. ONLY) Concrete slab adequate? \_\_\_\_\_ Size \_\_\_\_\_

Size of blow-off \_\_\_\_\_ Sample tap available Aux. esp. @ 2 wells

4) PUMP: Capacity 111 <sup>MIN</sup> 236 <sup>MAX</sup> 141 <sup>AVG</sup> Type pump VERT. TURB.

Height above floor (pump/casing) \_\_\_\_\_ High Service Pumps

1200 gpm (w/low power)  
750 gpm; 850 gpm; 500 gpm

5) TREATMENT: Is this a central treatment facility? YES (1 of 8)

Chlorinator: Type WET GAS Capacity 50 PPD In Service? YES

Spare parts or unit? SPARE UNIT Proper ventilation? YES Gas Mask? AIR PACK, REPAIR KIT & ALERT.

Aerator: Type NONE Condition \_\_\_\_\_

Filter(s): Type PRESSURE No. 6 Media SAND

Size 84" Ø Rate (gpm/ft<sup>2</sup>) 127 gpm ca Head loss ±5-10 lbs

Type controls \_\_\_\_\_ Condition \_\_\_\_\_

Comments BACKWASHED DAILY - ACCESS OPENINGS IN FILTER SIDES

Softeners: Type SPIRACTOR No. 1 Media SAND-CATALYST

Size 1.0 MG Rate (gpm/ft<sup>2</sup>) \_\_\_\_\_ Head loss \_\_\_\_\_

Type controls HYDRATED LIME - BAGS Condition MIXER MOTOR NOISY

Comments \_\_\_\_\_

Other treatment (Describe): NaF - in line before SATURATOR - MOTOR ON FILL LINE  
WET 747 PUMP

Process Wastewater treatment (Describe): DISCH. TO SEAL. SUIR

6) REMARKS AND RECOMMENDATIONS THIS TO BE RE-EVALUATED

DEPARTMENT OF HUMAN RESOURCES  
DIVISION OF HEALTH SERVICES  
\*WELL INFORMATION\*

WELL NO. \_\_\_\_\_

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - All wells

Sources of pollution/distance none - controlled by USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? yes

Properly drained? \_\_\_\_\_ Freeze protection? yes

Condition of house OK Locked? yes

3) WELL: Diameter varies Type const. GRAVEL Yield (GPM) varies Storage at well \_\_\_\_\_

Properly sealed? \_\_\_\_\_ Property owned: TOTAL 756 gpm

4 wells Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? yes

Concrete slab adequate? no - no drive @ 2 wells

Size of blow-off \_\_\_\_\_ Sample tap available yes

4) PUMP: Capacity MIN 104 MAX 300 AVG 189 Type pump VERT TURB (high service in WTP)

Height above floor (pump/casing) \_\_\_\_\_ Is pump leaking? \_\_\_\_\_

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type W/T GAS (150# cyl) Capacity 18/100 ppd In Service? yes (manual system)

Spare parts or unit? SPARE @ 30 ppd Proper ventilation? yes Gas Mask? AIRPACK; ALERT; REPAIR KIT

Aerator: Type PERMIT FORCED DRAFT Condition few OK - DETENTION TANK @ UNIT

Filter(s): Type PRESSURE (PERMIT) No. 3 Media SAND

Size 96" Ø Rate (gpm/ft<sup>2</sup>) 134 gpm ea Head loss 5#

Type controls MULTIPOINT Condition OK - ALL CONTROLS NOT AUTOMATIC

Comments B/W ea 3rd day

Softeners: Type PERMIT No. 2 Media Na Zeolite

Size 60" Ø Rate (gpm/ft<sup>2</sup>) 128 gpm ea Head loss 5-8#

Type controls MULTIPOINT Condition OK

Comments REGENERATE @ 1100 MG, BRINE CRY TANK INSIDE UNIT

Other treatment (Describe): LIME FEED FOR pH CONTROL & Fe REDUCTION

Process wastewater treatment (Describe): DISCHG. TO SAN. SWR

6) REMARKS AND RECOMMENDATIONS \_\_\_\_\_

WELL NO. \_\_\_\_\_

\*WELL INFORMATION\*

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL WELLS

Sources of pollution/distance CONTROLLED BY USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? YES

Properly drained? \_\_\_\_\_ Freeze protection? YES

Condition of house \_\_\_\_\_ Locked? YES

3) WELL: Diameter VARIES Type const. \_\_\_\_\_ Yield (GPM) VARIES Storage at well \_\_\_\_\_

Properly sealed? \_\_\_\_\_ ~~Properly sealed?~~ TOTAL 777 gpm

5 wells Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? @ WTP

Concrete slab adequate? \_\_\_\_\_ Size \_\_\_\_\_

Size of blow-off \_\_\_\_\_ Sample tap available YES

4) PUMP: Capacity MIN 104 MAX 240 AVG 155 Type pump VERT TURIS

Height above floor (pump/casing) \_\_\_\_\_ hi service pumps 20500 gpm  
1 @ 750 w/aux. drive

TREATMENT: Is this a central treatment facility? YES (one of eight)

Chlorinator: Type WET Capacity 15/100 ppd In Service? YES

Spare parts or unit? SPARE 100 ppd Proper ventilation? YES Gas Mask? AIR PACK, ALERT, REPAIR KIT

Aerator: Type PERMIT FORCED draft Condition FAN OK - DETENTION TANK

Filter(s): Type PERMIT - PRESSURE No. 6 Media \_\_\_\_\_

Size 96" Ø Rate (gpm/ft<sup>2</sup>) 94 gpm ea Head loss ≈ 5 #

Type controls MULTIPOINT Condition OK

Comments BACKWASHED DAILY

Softeners: Type PERMIT No. 4 Media Na Zeolite

Size 72" Ø Rate (gpm/ft<sup>2</sup>) 102 gpm ea Head loss 5 #

Type controls MULTIPOINT Condition OK

Comments REGENERATED @ 100 MG

Other treatment (Describe): LIME (Hydrated to slurry & pump - pH CONTROLLED FOR Fe REDUCTION)

Process Wastewater treatment (Describe): PHOSPHATE NOT IN SERVICE

↳ settling pond - discharging to ditch

e) REMARKS AND RECOMMENDATIONS

- ① BRINE DAY TANK inside Bldg, should have cover
- ② LIME & PO4 NOT NECESSARY TOGETHER (Should perform in plant trials to determine if lime may be discontinued)

DEPARTMENT OF HUMAN RESOURCES  
 DIVISION OF HEALTH SERVICES  
 \*WELL INFORMATION\*

WELL NO. \_\_\_\_\_

ID NO. \_\_\_\_\_

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL wells

Sources of pollution/distance CONTROLLED BY USMC

Adequate slope? \_\_\_\_\_ Flooding? \_\_\_\_\_

2) WELL HOUSE: Free of stored materials? YES

Properly drained? \_\_\_\_\_ Freeze protection? \_\_\_\_\_

Condition of house OK Locked? YES

3) WELL: Diameter VARIES Type const. GRAVEL Yield (GPM) VARIES Storage at well \_\_\_\_\_

Properly sealed? \_\_\_\_\_ Properly vented? TOTAL 369 gpm

2 wells Casing depth \_\_\_\_\_ Well depth \_\_\_\_\_ Meter Available? YES

Concrete slab adequate? \_\_\_\_\_ from Aug @ 1 well

Size of block-off \_\_\_\_\_ Sample tap available YES

4) PUMP: Capacity MAX 210 MIN 159 AVERAGE 185 Type pump VERT TURB

Height above floor (pump/casing) \_\_\_\_\_ SERVICE pumps  
1 @ 1000 gpm (2nd/aux drive)  
1 @ 750

5) TREATMENT: Is this a central treatment facility? YES (one of eight) 1 @ 300

Chlorinator: Type WET GAS (150#) Capacity 10/30 gpd In Service? YES

Spare parts or unit? spare 1 @ 50 gpd Proper ventilation? YES Gas Mask? AIR PACK, ALKIT, REPAIR KIT

Aerator: Type PRESSURIZED - IN LINE UNIT Condition OK - USES AIR COMPRESSOR

Filter(s): Type Calgon (Pressure units) No. 2 Media SAND

Size 48" Ø Rate (gpm/ft<sup>2</sup>) 37 gpm ea Head loss ± 5'

Type controls Manual cycle Condition OK

Comments Backwashed at 030mg - USES RAW WATER FOR B/W

Softeners: Type Calgon No. 2 Media Na Zeolite

Size 42" Ø Rate (gpm/ft<sup>2</sup>) 75 gpm ea Head loss ± 5'

Type controls Manual cycle Condition OK - New Resin in 1977

Comments Regenerated @ 080 mg

Other treatment (Describe): \_\_\_\_\_

Process wastewater treatment (Describe): Settling pond - pumped to ditch

6) REMARKS AND RECOMMENDATIONS ① Should use TPTD water for B/W ② Flow pattern s/b changed - now split thru filters & softeners - should all be thru filters then softener (to extend resin life & reduce iron in dist. system)